


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Stevens	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 1	Township number T 32 S	Range number R 37 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	8 N- 2 1/2 E of Hugoton.		3. Owner of well: R.R. or street: City, state, zip code:	Laurence Broken R.R. Moscow, Kan. 67952	
4. Locate with "X" in section below: N W E S 1 Mile	Sketch map: 		6. Bore hole dia. 10 in. Completion date 10-24-77 Well depth 420 ft.		
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
			9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC sch 40 Weight _____ lbs./ft. Dia. 5 in. to 410 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250		
			10. Screen: Manufacturer's name Slucom Type saw cut Dia. 5 Slot/gauze 1/8 Length 40 Set between 320 ft. and 340 ft. 400 ft. and 420 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/2		
			11. Static water level: _____ mo./day/yr. 210 ft. below land surface Date 10-24-77		
			12. Pumping level below land surfaces: 220 ft. after 1 hrs. pumping 22 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
			16. Nearest source of possible contamination: ft. 100 Direction NE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: _____ Not installed Manufacturer's name Reda Model number 19D15P HP 2 Volts 230 Length of drop pipe 280 ft. capacity 22 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Slucom Drilling 137 Business name License No. Address Hugoton Kan Signed Paul Blacum Date 10-24-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

32 37 1
Sec
1/4 1/4 1/4
NE 1/4 NW 1/4