


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Stevens</b>	Township name	Fraction <b>W<sup>1</sup>/<sub>2</sub> NW<sup>1</sup>/<sub>4</sub></b>	Section number <b>26</b>	Town number <b>T 32 S</b>	Range number <b>R 38 W</b>	
Distance and direction from nearest town or city:			3 Owner of well: <b>Keefe Farms #5</b>				
Street address of well location if in city:			Address: <b>% Walter Beesley, Box 156 Hugoton, Kansas 67951</b>				
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: <b>500</b> ft. Date of completion <b>4-3-75</b> Well diameter <b>26</b> in.	
2 Type and color of material  <b>See Attached</b>			From			To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
							6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
							7 Casing: Material <b>Steel</b> Height: <b>above</b> /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. _____ Weight <b>36</b> lbs./ft. <b>16</b> in. to <b>500</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ____ in. to ____ ft. depth
							8 Screen: Manufacturer <b>Brown</b> Type <b>Louvered</b> Dia. <b>16"</b> Slot/gauze <b>1/8"</b> Length <b>120'</b> Set between <b>365</b> ft. and <b>485</b> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/2 to 1/8</b>
							9 Static water level: <b>129</b> ft. below land surface Date <b>4-3-75</b>
							10 Pumping level below land surfaces: <b>164</b> ft. after ____ hrs. pumping <b>1275</b> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
							11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
							12 Well head completion: <b>12</b> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
							13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.
							14 Nearest source of possible contamination: <b>None Observed</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
(use a second sheet if needed)							15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
							17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drilling &amp; Supply 145</b> Business name License No. _____ Address <b>Box 639 Garden City Ks</b> Signed <b>Richard S. Henkle</b> Date <b>4/21/75</b> Authorized representative
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley <b>Rolling</b>							

*Keefer Farms #5*

CUSTOMERS NAME (3 W Land and Cattle Company) DATE 1-8-75  
 STREET ADDRESS \_\_\_\_\_ TEST # 1 E.L.Hole  
 CITY & STATE Hugoton, Kansas DRILLER Livingston  
 COUNTY Stevens QUARTER NW SECTION 26 TOWNSHIP 32 RANGE 38

LOCATION 100 Ft. West of Pivot

WELL LOCATION Well # 5

Drilled from	Feet	Footage to	Description of Strata	Static Water Level
				Proposed Well Depth
0		5	Slow sand	
5		40	Clay and sand st.	
40		48	Sand fine to med.	
48		78	Brown clay and few sand st.	
78		103	Sand fine to med., small gravel.	
103		114	Clay, limerock ledges, few fine sand st.	
114		131	Sand fine to med., few cemented ledges.	
131		175	Brown sandy clay, few limerock ledges, fine sand st.	
175		196	Sand fine, small	
40	196	60	256	Sand fine to med., few coarse, cemented ledges.
	256		266	Brown sandy clay and few fine sand st.
45	266	14	280	Sand fine to med, coarse
	280		355	Brown sandy clay and sand st.
65	355	95	450	Sand fine to med, coarse, small gravel.
	450		454	Clay and sand st.
70	454	20	474	Sand fine to med, coarse, small brown gravel, few tan rock. Very few clay st.
	474		480	Brown clay and few sand st.
50	480	07	487	Brown rock, sandstone and fine sand
	487		498	Red bed. Very hard.

106 TOTAL DEPTH OF WELL 500 Ft.

Set up west  
 Dig pit on the north.  
 Very sandy