

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Morton	Township name Richfield	Fraction NW NW NW	Section number 7	Town number 32S	Range number 39W
---------------------	-------------------------	-----------------------------------	-----------------------------	----------------------------	---------------------------	----------------------------

Distance and direction from nearest town or city: 10 miles east, 2 North of Richfield, Kansas Street address of well location if in city:	3 Owner of well: Robert Musgrove Address: N. Star Route Rolla, Kansas
---	--

Locate with "X" in section below: N W E S 1 Mile	Sketch map:	4 Well depth: 299.3 ft. Date of completion 3-31-75 Well diameter 27 in.
---	-------------	---

2	Type and color of material	From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
	Surface	0	2	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
	Sandy clay	2	59	7 Casing: Material steel Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 inch Weight 36.8 lbs./ft. 1 0 in. to 216.7 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth
	Coarse sand & gravel tight and hard	59	88	8 Screen: Manufacturer Lakewood Type steel Dia. 16" Slot/gauze 3/16 Length 2" slot Set between 216.7 ft. and 299.3 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range 1/4 x 5/8
	Sandy clay, lime shale & sand strips tight & hard	88	212	9 Static water level: 197.7 ft. below land surface Date 3-27-75
	Embedded sand	212	219	10 Pumping level below land surfaces: 221 ft. after 7.3 hrs. pumping 1479 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1600 g.p.m.
	Coarse sand w/cemented strips & yellow chalk 46ft.	219	273	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
	Yellow chalk, sandrock & Dakota 20%	273	296	12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
	Blue shale	296	300	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
				14 Nearest source of possible contamination: ft. 20 from corral Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
	(use a second sheet if needed)			

16 Remarks: elevation Drilled this well in the backyard of farm site Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name Box 487, Ulysses, KS. License No. Address Signed M. Beard Date 4-22-75 Authorized representative
---	--