


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Morton	Fraction SE 1/4 SW 1/4 SW 1/4	Section number 33	Township number T 32S	Range number S R 40	E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:				
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 			Well drilled near TH 1-75 which is in the SW 1/4, Sec. 33, T32S, R40W, Morton County, Ks.				
5. Type and color of material			From	To	6. Bore hole dia. 28 in. Completion date 10-25-75 Well depth 380 ft.		
Top soil			0	2	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Tan clay caliche streaks			2	70	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation Air conditioning <input type="checkbox"/> Stock Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine to coarse sand fine to coarse gravel			70	81	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 217 ft. depth Wall Thickness: inches or Dia. 16 in. to 380 ft. depth gage No. .219		
Tan clay fine sand lenses			81	139	10. Screen: Manufacturer's name Foster & Cook Type Mill slot & louver Dia. 16" Slot/gauze 1/8" Length 143 Set between 217 ft. and 360 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 2-5-9.2mm		
Tan and white clay			139	218	11. Static water level: mo./day/yr. 226 ft. below land surface Date 10-2-75		
Very fine to fine sand			218	237	12. Pumping level below land surfaces: 326 ft. after 1/2 hrs. pumping 780 g.p.m. 342 ft. after 1 hrs. pumping 818 g.p.m. Estimated maximum yield 750 g.p.m.		
Fine to coarse sand			237	257	13. Water sample submitted: mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date		
White to pink sandy clay, hard sandstone streaks, very fine sand lenses, v hard streaks			257	302	14. Well head completion: Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Fine to medium sand clay lenses			302	317	15. Well grouted? Yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Fine to coarse sand firm but not tight			317	337	16. Nearest source of possible contamination: unk ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Red sandy clay fine sand streaks			337	350	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Fine to coarse sand clay lenses			350	360	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 150 Business name License No. Address Garden City, Kansas Signed PL Vincent Date 10-25-75 Authorized representative		
Dakota Clay			360	436			
Red bed			436	540			
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

3240633
T
R
Sec
1/4
1/4
SW
SW