


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <u>Morton</u>	Fraction <u>SW 1/4 SW 1/4 SW 1/4</u>	Section number <u>35</u>	Township number <u>T 32</u>	Range number <u>S R 40 E/W</u>
2. Distance and direction from nearest town or city: <u>7 1/2 mi. Rolla</u>				3. Owner of well: <u>Mrs Bob Odar</u>		
Street address of well location if in city:				R.R. or street: City, state, zip code: <u>Rolla, Ka 67954</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date <u>5-9-79</u> Well depth <u>310</u> ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other <u>Fish Pond</u>
<u>blow sand brown</u>				<u>0</u>	<u>4</u>	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>13</u> in. RMP <input type="checkbox"/> PVC <u>40</u> Weight <input type="checkbox"/> lbs./ft. Dia. <u>5</u> in. to <u>310</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>1258</u>
<u>joint clays brown</u>				<u>4</u>	<u>12</u>	10. Screen: Manufacturer's name <u>Slocum</u> Type <u>saw cut</u> Dia. <u>5"</u> Slot/gauze <u>1/8</u> Length <u>20'</u> Set between <u>290</u> ft. and <u>310</u> ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8-1/4</u>
<u>Caliche buff + white</u>				<u>12</u>	<u>36</u>	11. Static water level: <input type="checkbox"/> mo./day/yr. <u>40</u> ft. below land surface Date <u>5-9-79</u>
<u>Sand + Gravel brown + black (Coarse)</u>				<u>36</u>	<u>40</u>	12. Pumping level below land surfaces: <u>154</u> ft. after <u>2</u> hrs. pumping <u>50</u> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.
<u>clay balls buff</u>				<u>40</u>	<u>140</u>	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
<u>silt balls w/silty sand tan</u>				<u>140</u>	<u>188</u>	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>13</u> inches above grade
<u>" " Reddish w/silty sand</u>				<u>188</u>	<u>220</u>	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>13</u> ft.
<u>" " Gray</u>				<u>220</u>	<u>240</u>	16. Nearest source of possible contamination: <u>?</u> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<u>Marrel greenish yellow w/rock shell</u>				<u>240</u>	<u>290</u>	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Beda</u> Model number <u>UD35P</u> HP <u>3</u> Volts <u>230</u> Length of drop pipe <u>168</u> ft. capacity <u>50</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
<u>Dakota sand mixed claysilts w/tan sand</u>				<u>290</u>	<u>310</u>	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Slocum Drilling 127</u> Business name License No. Address <u>Hogaten Ka 67951</u> Signed <u>Paul Slocum</u> Date <u>6-11-79</u> Authorized representative
<u>red silts + silt stone hard</u>				<u>310</u>	<u>320</u>	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						