


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Morton	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 4	Township number T 32	Range number R 43
2. Distance and direction from nearest town or city: 19N 5W 1N Street address of well location if in city: ELKHART-KANS				3. Owner of well: Kenneth Frownfelter R.R. or street: City, state, zip code: MANter-KANS 67862		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div> 				Sketch map: 6. Bore hole dia. 6 3/4 in. Completion date 6-10-77 Well depth 100 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC PVC Weight 250 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
				10. Screen: Manufacturer's name Type PLASTIC Dia. 5" Slot/gauze 1/8" Length 20 Set between 60 ft. and 80 ft. Gravel pack? yes Size range of material 1/4		
				11. Static water level: 50 ft. below land surface Date 6-10-77		
				12. Pumping level below land surface: AIR Developed 80 ft. after 2 hrs. pumping 30 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 18 inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: WINDMILL <input checked="" type="checkbox"/> installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 90 ft. capacity 30 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input checked="" type="checkbox"/> Centrifugal WINDMILL <input checked="" type="checkbox"/> Other		
				18. Elevation:		
19. Remarks: This well stock well with windmill Cemented & Base Run				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. R.S. F. Drilling Inc 154 Business name License No. Address Springfield, Mo. 65703 Signed Ralph K. Woods Date 7-10-77 Authorized representative		