USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Morton	SW 1/4 SW 1/4 SW 1/4	20	T 32 S	R 43 E/W

2. Distance and direction from nearest town or city: 13 mi W 1S. of Richfield, Ks.
Street address of well location if in city:

3. Owner of well: U.S. Forrest Service
R.R. or street:
City, state, zip code: Elkhart, Ks. 67950

4. Locate with "X" in section below: Sketch map:

N
NW NE
W E
SW SE
S
1 Mile
1 Mile

6. Bore hole dia. 9 in. Completion date 5/26/77
Well depth 140 ft.

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material Pits Height: Above or below
Threaded __ Welded gl Surface 14 in.
RMP __ PVC X Weight __ lbs./ft.
Dia. 5 in. to 60 ft. depth Wall Thickness: inches or
Dia. __ in. to __ ft. depth gage No. 0.258

5. Type and color of material	From	To
Overburden	0	57
Clay + Thin Streaks of fine Sand	57	100
Medium to Coarse Sand + Clay Streaks	100	137
Redbed	137	140

(Use a second sheet if needed)

10. Screen: Manufacturer's name J + L
Type PVC Dia. 5"
Slot/gauze 1/16 Length 80
Set between 60 ft. and 140 ft.
__ ft. and __ ft.
Gravel pack? Yes Size range of material 1/8"

11. Static water level: mo./day/yr.
57 ft. below land surface Date 5/26/77

12. Pumping level below land surfaces:
__ ft. after __ hrs. pumping __ g.p.m.
__ ft. after __ hrs. pumping __ g.p.m.
Estimated maximum yield 25 g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date

14. Well head completion:
__ Pitless adapter 14 Inches above grade

15. Well grouted? Yes
With: X Neat cement __ Bentonite __ Concrete
Depth: From 3 ft. to 13 ft.

16. Nearest source of possible contamination:
ft. __ Direction __ Type __
Well disinfected upon completion? X Yes __ No

17. Pump: X Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
__ Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

T 32 R 43 E/W Sec 20 1/4 1/4 1/4 SWSWSW

18. Elevation:

Topography:
__ Hill
__ Slope
__ Upland
__ Valley

19. Remarks: 16. None. Pasture Well

17 Well to be Completed by:
Stout Water Well
Elkhart. Ks. 67950

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name J+W Water Well License No. 142
Address Box 816 Liberal, Ks
Signed C.A. Wagenschein Date 6/27/77
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5