

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Harper</b>	Fraction <b>SW 1/4 SW 1/4 SW 1/4</b>	Section number <b>5</b>	Township number <b>32</b>	Range number <b>5</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: <b>Catholic church</b> R.R. or street: City, state, zip code: <b>Danville. Ks/ 67036</b>		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <b>8</b> in. Completion date <b>4-3-79</b> Well depth <b>65</b> ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material _____ Height: <b>22</b> Above or below Threaded _____ Welded _____ Surface <b>22</b> in. RMP _____ PVC <input checked="" type="checkbox"/> Weight <b>282</b> lbs./ft. Dia. <b>5</b> in. to <b>65</b> ft. depth! Wall Thickness: inches or Dia. _____ in. to _____ ft. depth! gage No. <b>258</b>		
			10. Screen: Manufacturer's name <b>Pumpco</b> Type <b>PVC</b> Dia. <b>5</b> Slot/gouze <b>025</b> Length <b>10</b> Set between <b>33</b> ft. and <b>65</b> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/2 in</b>		
			11. Static water level: <b>22</b> ft. below land surface Date <b>4-30-79</b> _____ ft. below land surface Date _____		
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>50</b> g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <b>20</b> Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>3</b> ft. to <b>15</b> ft.		
			16. Nearest source of possible contamination: ft. <b>60</b> Direction <b>N</b> Type <b>old well</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:  <b>customer to build pump house</b>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Lyman Bros</b> <b>140</b> Business name <b>ML</b> License No. Address _____ Signed <b>W. Lyman</b> Date <b>4-30-79</b> Authorized representative		

*They were told they should plug old well after hooking new one old well still in use*

3  
10  
- 5  
5  
1/4  
1/4  
1/4