USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Comanche	Protection	NW¼ NW¼ NE¼	5	33S	20W

Distance and direction from nearest town or city: 1½ mi. west of
Street address of well location if in city: NW corner of Protection

3 Owner of well: Herschel Morris
Address: Hays, Kans.

Locate with "X" in section below:



Sketch map:

2 Type and color of material	From	To
Topsoil	0	1
red clay	1	35
river mud (fine red sand)	35	52
soft red sandstone	52	62

(use a second sheet if needed)

4 Well depth: 62 ft. Date of completion 5-15-76
Well diameter 9 in.

5 [X] Cable tool [ ] Rotary [ ] Driven [ ] Dug
[ ] Hollow rod [ ] Jetted [ ] Bored [ ] Reverse rotary

6 Use: [ ] Domestic [ ] Public supply [ ] Industry
[ ] Irrigation [ ] Air conditioning [ ] Commercial
[ ] Test well [X] Pasture

7 Casing: Material GMP Height: above/below
Threaded [ ] Welded [ ] Surface 15 in.
Diam. 5 in. to 62 ft. depth Weight ___ lbs./ft.
___ in. to ___ ft. depth Drive shoe? [ ] Yes [ ] No

8 Screen:
Manufacturer Jess + Lowell
Type RMP Dia. 5
Slot/gauze 40W Length 10'
Set between 52 ft. and 62 ft.
Fittings:
Gravel pack [X] Yes [ ] No Size range of material ¾ down

9 Static water level:
39 ft. below land surface Date 5-15-76

10 Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

11 Water sample submitted:
[ ] Yes [ ] No Date ___

12 Well head completion:
[ ] Pitless adapter 23 inches above grade

13 Well grouted? [X] Yes [ ] No
[ ] Neat cement [ ] Bentonite [X] cons'd
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination:
ft. ___ Direction none Type ___
Well disinfected upon completion? [X] Yes [ ] No

15 Pump: [ ] Not installed
Manufacturer's name aermotor
Model number ___ HP wind Volts ___
Length of drop pipe 57 ft. capacity ___ g.m.p.
Type:
[ ] Submersible [ ] Turbine
[ ] Jet [X] Reciprocating
[ ] Certrifugal [ ] Other

16 Remarks: elevation

Topography:
[ ] Hill
[X] Slope
[ ] Upland
[ ] Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Wymer Blacksmith Shop 22
Business name License No.
Address Protection Ks. L-7121
Signed Kenneth Lechner Date 5-16-76
Authorized representative

33 20W 5 NWNE

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

677-H