

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction SE 1/4 NW 1/4 NW 1/4	Section number 17	Township number T 33 S	Range number R 26 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:		8E, 5S, 2E, 3S, 2W of Meade				
3. Owner of well: R.R. or street: City, state, zip code:		Olis G. Lauppe Star Route B Fowler, Kansas				
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: Slope well Sand Creek		6. Bore hole dia. 8 1/2 in. Completion date 12-10-79 Well depth 55 ft.				
5. Type and color of material		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
sand		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
gravel		9. Casing: Material <input type="checkbox"/> Height: <input type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 55 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gauge No. 40 ad.				
red bed		10. <input checked="" type="checkbox"/> Screen: Manufacturer's name Jet Stream Type PVC Dia. 5" Slot/gauze 1/4" Length 30' Set between 25 ft. and 55 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4"-1/2"				
BR 26' /m		11. Static water level: <input checked="" type="checkbox"/> mo./day/yr. 4 ft. below land surface Date 12-10-79				
		12. Pumping level below land surfaces: 50 ft. after 1 1/2 hrs. pumping 10 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 15 g.p.m.				
		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>				
		14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade				
		15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 3 ft.				
		16. Nearest source of possible contamination: ft. 30 Direction South Type Creek Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
		17. Pump: Sec 19 <input type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
18. Elevation: 2222 /m Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: windmill well				
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ralph B. Burt 101 D Business name Smale K License No. <input type="checkbox"/> Address Star Route B Signed Ralph B. Burt Date 12-21-79 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5