


1 LOCATION OF WATER WELL		Fraction	Section Number		Township Number		Range Number	
County: Meade		NW 1/4 NE 1/4 SW 1/4	4		T 33 S		R 28 EW	
Distance and direction from nearest town or city? 5 South, 2 West, 1/2 South and 1/4 East of Meade, Ks.				Street address of well if located within city?				
2 WATER WELL OWNER: Southwest Gas Storage, Underground Storage Division								
RR#, St. Address, Box #: Box 959				Board of Agriculture, Division of Water Resources				
City, State, ZIP Code: Meade, Kansas 67864				Harris 1-4		Application Number: ----		
3 DEPTH OF COMPLETED WELL: 123 ft. Bore Hole Diameter: 9 7/8 in. to 123 ft. and 123 in. to 123 ft.								
Well Water to be used as:								
1 Domestic			3 Feedlot			5 Public water supply		
2 Irrigation			4 Industrial			7 Lawn and garden only		
8 Air conditioning			9 Dewatering			11 Injection well		
10 Observation well			12 Other (Specify below)					
Well's static water level: 4 Above Artesian ft. below land surface measured on December month 15 day 1980 year								
Pump Test Data: 100+ gpm: Well water was 100+ ft. after 100+ hours pumping 100+ gpm								
4 TYPE OF BLANK CASING USED:								
1 Steel			3 RMP (SR)			5 Wrought iron		
2 PVC			4 ABS			6 Asbestos-Cement		
7 Fiberglass			8 Concrete tile			9 Other (specify below)		
Casing Joints: Glued XXX Clamped			Welded			Threaded		
Blank casing dia: 5 in. to 63 ft. Dia: 5 in. to 63 ft. Dia: 5 in. to 63 ft.								
Casing height above land surface: 12 in., weight 2.8 lbs./ft. Wall thickness or gauge No. 265								
TYPE OF SCREEN OR PERFORATION MATERIAL:								
1 Steel			3 Stainless steel			5 Fiberglass		
2 Brass			4 Galvanized steel			6 Concrete tile		
8 RMP (SR)			9 ABS			11 Other (specify)		
12 None used (open hole)			10 Asbestos-cement					
Screen or Perforation Openings Are:								
1 Continuous slot			3 Mill slot			5 Gauzed wrapped		
2 Louvered shutter			4 Key punched			7 Torch cut		
9 Drilled holes			11 None (open hole)			10 Other (specify)		
Screen-Perforation Dia: 5 in. to 123 ft. Dia: 5 in. to 123 ft. Dia: 5 in. to 123 ft.								
Screen-Perforated Intervals: From 63 ft. to 123 ft. From 63 ft. to 123 ft. From 63 ft. to 123 ft.								
Gravel Pack Intervals: From 14 ft. to 123 ft. From 14 ft. to 123 ft. From 14 ft. to 123 ft.								
5 GROUT MATERIAL: XXX Neat cement 2 Cement grout 3 Bentonite 4 Other								
Grouted Intervals: From 4 ft. to 14 ft. From 4 ft. to 14 ft. From 4 ft. to 14 ft.								
What is the nearest source of possible contamination:								
1 Septic tank			4 Cess pool			7 Sewage lagoon		
2 Sewer lines			5 Seepage pit			8 Feed yard		
3 Lateral lines			6 Pit privy			9 Livestock pens		
10 Fuel storage			11 Fertilizer storage			14 Abandoned water well		
12 Insecticide storage			XXX 16 Other (specify below)			15 Oil well/Gas well		
13 Watertight sewer lines			Creek					
Direction from well: East How many feet: 500 ? Water Well Disinfected? Yes XX No								
Was a chemical/bacteriological sample submitted to Department? Yes XXX No XXX If yes, date sample was submitted: XXX month XXX day XXX year: Pump Installed? Yes XX Rental No								
If Yes: Pump Manufacturer's name: Aermotor Model No. 2 HP 2 Volts 220								
Depth of Pump Intake: 2 ft. Pumps Capacity rated at 2 gal./min.								
Type of pump: XXX Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other								
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on December month 15 day 1980 year								
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 252								
This Water Well Record was completed on December month 31 day 1980 year under the business name of Friesen Windmill & Supply Inc. by (signature) [Signature]								
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG	
		0	4	Topsoil				
		4	9	Clay				
		9	16	Fine Sand				
		16	40	Blue Clay				
		40	58	Blue Fine Sand				
		58	100	Blue Clay				
		100	124	Med. to Lar. Sand				
		124	160	Clay w/Sm.Streaks Fine Sand				
ELEVATION: Valley								
Depth(s) Groundwater Encountered 1... Not available ft. 3 1 ft. 4 1 ft. (Use a second sheet if needed)								
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.								

OFFICE USE ONLY

T

33

R

25

EW

SEC.

4

NW 1/4 NE 1/4 SW 1/4