


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sumner	Fraction NE 1/4 NE 1/4	Section number 26	Township number T 33 S	Range number R 3W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	2 1/4 West of Mayfield, Kansas and 7 South and 1 West on the South Side of the Road.		3. Owner of well: R.R. or street: City, state, zip code: Triple R. Farms R. R. #3 Wellington, Kansas		
4. Locate with "X" in section below: Sketch map: 	6. Bore hole dia. 11 in. Completion date _____ Well depth 48 ft. 1-3-77		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Topsoil	0	2	9. Casing: Material styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMK <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 48 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 200		
Clay	2	12	10. Screen: Manufacturer's name _____ Sunflower Plastic Type styrene Dia. 5" Slot/gauge .06 Length 8' Set between 48 ft. and 48 ft. Gravel pack? yes Size range of material 1/4-1/8"		
Fine Sand	12	27	11. Static water level: _____ mo./day/yr. 27 ft. below land surface Date 1-3-77		
Clay	27	42	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Medium Sand	42	48	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.		
			16. Nearest source of possible contamination: Septic Tank ft. 100 Direction North Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 1-3-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5