


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 21	Township number T 33 S R 30	Range number EW
2. Distance and direction from nearest town or city: 6 miles S of Plains, 1/2 mile South Street address of well location if in city:				3. Owner of well: V.V. McVey R.R. or street: City, state, zip code: Kismet, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date 3-11-76 Well depth 453 ft.		
		500' N, 50' E of the SW corner of the NE 1/4, Sec. 21, T33S, R30W, Meade County, Kansas		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top soil				0	4	9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 210 ft. depth Wall Thickness: inches or Dia. 16 in. to 210 ft. depth gage No. 219
Fine sand				4	18	10. Screen: Manufacturer's name Brown, Doerr and Foster Type Louver & Millslot Dia. 16" Slot/gauze 1/8" Length 243' Set between 210 ft. and 453 ft. ft. and 453 ft. Gravel pack? Yes Size range of material 3.4mm
Tan clay				18	88	11. Static water level: 183 ft. below land surface Date 1-17-76 mo./day/yr.
Fine to coarse sand				88	104	12. Pumping level below land surfaces: 197 ft. after 1/2 hrs. pumping 1060 g.p.m. 221 ft. after 1 hrs. pumping 2460 g.p.m. Estimated maximum yield 3000 g.p.m.
Tan clay				104	134	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 1-17-76 mo./day/yr.
Fine to coarse sand				134	176	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> X Inches above grade
Blue clay				176	212	15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Fine to coarse sand clay streaks				212	314	16. Nearest source of possible contamination: Unk ft. Unk Direction Unk Type Unk
Fine to coarse sand				314	402	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Blue clay				402	416	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 12KM HP 1 Volts 1000 Length of drop pipe 260 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Fine to coarse sand				416	453	
Tan clay				453	480	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne - Western Co. 150 Business name License No. Address Garden City Signed [Signature] Date 5-21-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5