


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

CWW Inv. #14124

Shelman #1

1. Location of well:		County <b>Meade</b>	Fraction <b>1/4 NW 1/4 NW 1/4</b>	Section number <b>31</b>	Township number <b>T 33S S</b>	Range number <b>R 30W E/W</b>
2. Distance and direction from nearest town or city: <b>Go East of Liberal to Meade Co. Lake Rd. - Then 6m East - 2 1/4m South-East to location.</b>				3. Owner of well: <b>Sage Drilling Company</b> R.R. or street: <b>500 Bitting Building</b> City, state, zip code: <b>Wichita, Kansas 67202</b>		
4. Locate with "X" in section below: 				6. Bore hole di <u>9</u> in. Completion date <b>12-19</b> Well depth <b>320</b> ft.		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay				9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>28</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <b>2.78</b> lbs./ft. Dia. <b>5</b> in. to <b>210</b> depth Wall Thickness: inches or Dia. <b>5</b> in. to <b>320</b> depth gage No. <b>265</b>		
Medium to large sand				10. Screen: Manufacturer's name <b>Sawed perf.</b> Type <b>PVC</b> Dia. <b>5"</b> Slot/gauze <b>.030</b> Length <b>80'</b> Set between <b>210</b> ft. and <b>290</b> ft. Gravel pack? <b>yes</b> Size range of material <b>1/8-3/16</b>		
Sandy clay				11. Static water level: <b>185</b> ft. below land surface Date <b>12-19-77</b> mo./day/yr.		
Medium to large sand & sandy clay 80-20				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <b>50</b> g.p.m.		
Blue clay				13. Water sample submitted: <b>Yes</b> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
Medium to large sand				14. Well head completion: <b>28</b> inches above grade Pitless adapter <input type="checkbox"/>		
Blue clay & Medium to large sand 40-60				15. Well grouted? <b>yes</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
Blue clay				16. Nearest source of possible contamination: ft. <b>100</b> Direction <b>NE</b> Type <b>oil well</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Carlile Water Well 118</b> Business name License No. ____ Address <b>Box 275, Liberal, KS</b> Signed <b>Edward E. Means</b> Date <b>1-6-</b> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5