

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Meade	Fraction Center of SE$\frac{1}{4}$ 1/4 1/4 1/4	Section number 35	Township number 33 S	Range number 30 E W
2. Distance and direction from nearest town or city: 8 South of Plains, 2 East, 3/4 South, 1/4 West Street address of well location if in city:			3. Owner of well: Warren Fox R.R. or street: R. R. City, state, zip code: Plains, KS 67869		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: SE$\frac{1}{4}$, Sec. 35, T33S, R30W, Meade County, Kansas		
5. Type and color of material			From	To	6. Bore hole dia. 28 in. Completion date _____ Well depth 396 ft. 12-12-79
Surface			0	3	7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary
Fine sand clay streaks			3	15	8. Use: _____ Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____
Brown clay			15	74	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 37 lbs./ft. Dia. 16 in. to 262 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .219
Medium and coarse sand			74	195	10. Screen: Manufacturer's name Doerr & Foster Type Louver: M/S Dia. 16" Slot/gauze 1/8 Length 134 Set between 262 ft. and 396 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material: 2.8 mm
Blue clay			195	222	11. Static water level: _____ mo./day/yr. 170 ft. below land surface Date 11-10-79
Fine medium sand			222	253	12. Pumping level below land surfaces: 186 ft. after 1 1/2 hrs. pumping 1139 g.p.m. 198 ft. after 1 hrs. pumping 1865 g.p.m. Estimated maximum yield 2000 g.p.m.
Blue clay			253	262	13. Water sample submitted: _____ mo./day/yr. _____ Yes <input checked="" type="checkbox"/> No Date _____
Fine medium sand			262	366	14. Well head completion: _____ Pitless adapter 12 Inches above grade
Blue clay			366	378	15. Well grouted? Yes With: _____ Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.
Fine medium sand			378	396	16. Nearest source of possible contamination: _____ ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No
Fine sand clay streaks			396	426	17. Pump: _____ Not installed Manufacturer's name Layne & Bowler Model number 12KH HP 120 Volts _____ Length of drop pipe 280 ft. capacity 1000 g.p.m. Type: _____ Submersible <input checked="" type="checkbox"/> Turbine _____ _____ Jet _____ Reciprocating _____ _____ Centrifugal _____ Other _____
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name _____ License No. _____ Address Garden City, KS 67846 Signed [Signature] Date 12-14-79 Authorized representative		
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5