


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X Location of well:		County Seward	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 8	Township number T 33 S R 32 E/W
X Distance and direction from nearest town or city: of Liberal. 3E.		12 Miles north		3. Owner of well: Cecil Milhon R.R. or street: 824 South New York City, state, zip code: Liberal, Kansas	
4. Locate with "X" in section below:		Sketch map: 1768' South and 66' east of the NW corner of the NE 1/4, Sec. 8, T33S, R32W, Seward County, Kansas.		6. Bore hole dia. 28 in. Completion date 6-28-76 Well depth 258 ft.	
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From To		8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>	
Top soil		0 2		9. Casing: Material Stl. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 16 PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 121 ft. depth Wall Thickness: inches or Dia. 16 in. to 121 ft. depth gage No. 219	
Coarse sand to medium gravel		2 38		10. Screen: Manufacturer's name Foster Doerr Type Louvered, milslot Dia. 16" Slot/gauze 1/8" Length 137 Set between 121 ft. and 258 ft. ft. and 258 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3.4 mm	
Coarse sand medium gravel (clay streaks)		38 62		11. Static water level: 104 ft. below land surface Date 4-19-76 mo./day/yr.	
Tan clay		62 70		12. Pumping level below land surfaces: 130 ft. after 1/2 hrs. pumping 2019 g.p.m. 140 ft. after 1 hrs. pumping 2453 g.p.m. Estimated maximum yield 2500 g.p.m.	
Coarse sand to medium gravel (clay streaks)		70 104		13. Water sample submitted: unk mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date	
Coarse sand medium gravel		104 118		14. Well head completion: unk Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
Tan clay		118 126		15. Well grouted? Yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.	
Coarse sand medium gravel		126 258		16. Nearest source of possible contamination: unk ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Caliche and tan clay (hard)		258 268		17. Pump: Layne & Bowler Not installed Manufacturer's name 12KM HP 100 Volts Model number 200 ft. capacity 800 g.p.m. Length of drop pipe 200 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Red clay - red bed		268 300		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name Garden City, Kansas License No. Address 18 Nov 76 Signed Authorized representative Date	
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5