

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Seward		Fraction SE 1/4 SE 1/4 NW 1/4		Section number 9		Township number T 33 S R 33 E/W		Range number	
2. Distance and direction from nearest town or city: 10 mi N. of Liberal Street address of well location if in city:				3. Owner of well: C. Hanning R.R. or street: RFD #2 City, state, zip code: Liberal, Kansas					
4. Locate with "X" in section below: US 83				Sketch map:		6. Bore hole dia. 12 1/4 in. Completion date 5-8-77 Well depth 300 ft.			
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material <input checked="" type="checkbox"/> Thru Height: 0 Above or below Threading: <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP: <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight: _____ lbs./ft. Dia. 6 in. to 300 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 280		10. Screen: Manufacturer's name _____ Type Hand Slotted Slot/gauze 5/16 Dia. 6" Set between 240 ft. and 300 ft. Gravel pack? Yes Size range of material 4-8			
5. Type and color of material				From		To		11. Static water level: _____ mo./day/yr. 156 ft. below land surface Date 5-8-77	
Top Soil				0		2		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Fine Sand & Silt				2		23		13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Pea Gravel with clay				23		54		14. Well head completion: <input type="checkbox"/> Pitless adapter 16 inches above grade	
Coarse Sand with clay				54		80		15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Clay Stra				80		96		16. Nearest source of possible contamination: ft. 2500 Direction NE Type Gas Well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Fine Sand				96		103		17. Pump: Wind Mill <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe 175 ft. capacity 2 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay Stra				103		111		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Combs Eng 342 Business name Box 279 Turpin, OK License No. _____ Address _____ Signed Neal Combs Date 6-8-77 Authorized representative	
Coarse Sand				111		146			
Clay				146		149			
Coarse Sand & Clay				149		155			
Coarse Sand				155		185			
Coarse Sand & Clay Stra				185		300			
(Use a second sheet if needed)									
18. Elevation:		19. Remarks:							
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley									

33 330 - 9 SE SE NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5