

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Seward	Fraction NW 1/4 SW 1/4 SW 1/4	Section number 9	Township number T 33 S R 33 E/W	Range number
2. Distance and direction from nearest town or city: 10 mi. north of Liberal Street address of well location if in city:				3. Owner of well: F. E. Canning ham R.R. or street: RT 2 Liberal Kansas City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 8 3/4 in. Completion date 5-15-77 Well depth 300 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 300 ft. depth Wall Thickness: inches or ? Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258		
Top Soil		0	2	10. Screen: Manufacturer's name Hand Perforated Type PVC Dia. 5" Slot/gauze 1/8" Length 40' Set between 260 ft. and 300 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4-1/2		
fine sand & silt		2	25	11. Static water level: 160 ft. below land surface Date 5-15-77 mo./day/yr.		
Light Clay		25	58	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping N/A g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 100 g.p.m.		
Clay & fine sand		58	108	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Large sand		108	300	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
fast Drilling				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 360 Direction W Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number <input type="checkbox"/> HP 2 Volts 230 Length of drop pipe 260 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address <input type="checkbox"/> Signed <input type="checkbox"/> Authorized representative <input type="checkbox"/> Date <input type="checkbox"/>		
18. Elevation:	19. Remarks: This well drilled by owner			20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 33 R 33 E
 Sec 9
 1/4 1/4 1/4