USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

T	R	EW	sec	1/4	1/4	1/4	No.

Kansas State Dept. Of Health (Water Well Contractors) Forbes–Bldg. 740 Topeka, Kansas 66620

County Township name Fraction 1 Location of well:	Secti	on number	Town number Range number			
Seward NE,SW,SW		23	33S 33W			
	ner of wel		eve Burgess			
Str. Coddes of Eli Liberta Liv:	dress:		N. Sherman peral, Kansas			
Locate with "X" in section below: Sketch map:			4 Well depth: 383 ft. Date of completion 6-24			
N			Well diameter 28 in.			
Well drilled near	cent	er	5 Cable tool Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary			
of SW4, Sec. 23, T	•		6 Use: Domestic Public supply Industry			
W E R33W, Seward Count	y, K	s.	Irrigation Air conditioning Commercial			
			Test well			
			7 Casing: Material Stl Height: above/below Threaded Welded Surface 12 in.			
S			Diam. Weight _3/_ lbs./ft			
→ 1 Mile →						
2 Type and color of material	From	То	8 Screen:			
Sandy soil	0	2	Mgnufacturer Foster & Doerr Mill slot & louver 16"			
Sanay soil		4	Slot/gauze 1/8" Length 180			
Fine sand	2	15	Slot/gauze 1/8" Length 180 Set between 203 ft. and 383 ft.			
Tan clay with fine sand	15	42	Fittings: Gravel pack *** System - 9mm Gravel pack *** No Size range of material —			
Fine to coarse sand medium gravel	42	52	9 Static water level: 189 ft. below land surface Date 6-26-75			
Tan clay with limestone streaks	52	101	10 Pumping level below land surfaces:			
•			205 ft. after 4 hrs. pumping 1100 g.p.m. ft. after 1 hrs. pumping 2070 g.p.m.			
Fine to coarse sand medium gravel	101	259	Estimated maximum yield 2500 g.p.m.			
Tan and green clay with sand & gravel	259	281	11 Water sample submitted:			
Fine to coarse sand medium gravel	281	346	Yes ★★No Date 12 Well head completion:			
Tan clay	346	365	Pitless adapter Inches above grade			
Tun Clay	1340	303	13 Well grouted? Yes No			
Fine to coarse sand medium gravel	365	383	□ Neat cement Bentonite □			
Tan & green clay	383	420	14 Nearest source of possible contamination: unk			
			ft Direction Type Well disinfected upon completion? YE Yes No			
			15 Pump: Not installed			
			Manufacturer's name Layne Model number 12K HP 100 Volts 480			
			Length of drop pipe 260 ft. capacity 800 g.m.p.			
			Type: Submersible Turbine			
		†	Jet Reciprocating			
(use a second sheet if needed)		l	Certrifugal Other			
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this			
			report is true to the best of my knowledge and belief.			
Topography:			Business name License No.			
Slope			Address Box 686 Garden City			
Upland			Signed Authorized laptesenture 20			