## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County Fraction			Section number		Township number Range number	
1. Location of well:	Seward	SE 1/4 NW 1/4 NW	1/4	24		T 33 S R 33 E/W	
2. Distance and direc		N, 3E, 4S,		er of well		eve Burgess	
Liberal Kansas Street address of well location it in city:							
City, sta					ate, zip code:Liberal, Kansas		
4. Locate with "X" in section below:  N						6. Bore hole dia. 28 in. Completion date 2-7-77  Well depth 424 ft.	
ī					ŀ	7 Cable tool Rotary Driven Dug	
i	Pivot poir	nt of the NW4,	Sec.	24,	Т33	Hollow rod Jetted Bored XXReverse rotary	
R33W, Seward County, Kansas					Ì	8. Use: Domestic Public supply Industry	
						XX Irrigation Air conditioning Stock	
SW SE					}	Lawn Oil field water Other  9. Casing: MaterialStl Height: Above or below	
						Threaded Welded Surface in.	
s						RMP PVC Weight 37 lbs./ft.	
1 M				Τ.		Dia. 16 in. to 185 ft. depth Wall Thickness: inches or Diain. to ft. depth gage No219	
5. Type and color of	material			From	То	10. Screen: Manufacturer's name <u>Doerr</u> , Foster	
				h	38	houvered, millslot 16"	
Top soil					30	Slot/gauze 1/8" Length 239	
Fine to c	oarse sand			38	66	Set between185ft. andft.	
Tan clay	with sand streaks	<b>.</b>		66	97	ft. and ft.  Gravel pack? X Size range of material 4.4 mm	
			1			11. Static water level: mo./day/yr.	
Fine to c	oarse sand, fine	to meatum grav	/e				
with clay	streaks			97	196	12. Pumping level below land surfaces:  190 ft. after hrs. pumping 1016g.p.m.	
Fine to coarse sand, fine to medium gravel				196	284		
Fine to coarse sand, fine to medoum gravel						13. Water sample submitted: mo./day/yr.	
with clay streaks				284	424	1	
Fine to medium sand, dirty				424	586	Pitless adapter Inches above grade  15. Well grouted?	1.
				506		With: Neat cement Bentonite Concrete	h
Red bed	V-01-200-0-1	· · · · · · · · · · · · · · · · · · ·	-	586	600	Depin: From II. IO II.	ĮΩ.
						16. Nearest source of possible contamination: UNK ft Direction Type	
						Wall disinfected upon completion? X Yes No.	ψ
						17. rump:	M
					$\vdash$	Manufacturer's name Layne & Bowler  Model number 12K HP 100 Volts 460	$\sim$
							( <u>§</u> )"
						Type: Submersible Turbine	_
	· · · · · · · · · · · · · · · · · · ·					Jet Reciprocating	20
ļ	(Use a second s	heet if needed)				Centrifugal Other	N
18. Elevation:	9. Remarks:					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report	<u>ا</u> `
						is true to the best of my knowledge and belief.	3
Topography:						Layne-Western Co., Inc. 102	10
Hill Slope						Business name  License No.  Address Garden City, Kansas	2
X Upland						Signed P Linux Date	5
Valley						Authorized representative /4 Fab 71	12