


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Seward	Township name	Fraction SE, NW, NW	Section number 26	Town number 33S	Range number 33W
Distance and direction from nearest town or city: 7 miles N, 2E, 3/4 N, 1/4 E of Liberal Street address of well location if in city:				3 Owner of well: Steve Burgess Address: 512 N. Sherman Liberal, Kansas		
Locate with "X" in section below: N  S 1 Mile		Sketch map: Well drilled near center of NW 1/4, Sec. 26, T33S, R33W, Seward County, Kansas.		4 Well depth: 402 ft. Date of completion 6-13-75 Well diameter 28 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material stl Height: above /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. _____ Weight _____ lbs./ft. _____ 16 in. to 402 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
				8 Screen: Manufacturer Foster & Doerr Type Mill slot & lower 16" Slot/gauze 1/8" Length 201 Set between 201 ft. and 402 ft. Fittings: _____ Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____		
Sandy soil				0	2	9 Static water level: 182 ft. below land surface Date 6-23-75
Fine sand with tan clay streaks				2	30	10 Pumping level below land surfaces: 192 ft. after 1/2 hrs. pumping 963 g.p.m. 210 ft. after 1 hrs. pumping 2155 g.p.m. Estimated maximum yield 2500 g.p.m.
Fine to coarse sand medium gravel				30	39	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Tan clay with light gravel streaks				39	62	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade
Blue clay with limestone streaks				62	68	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.
Tan clay & limestone streaks				68	93	14 Nearest source of possible contamination: unk ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Fine to coarse sand medium gravel				93	131	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 12K HP 100 Volts 480 Length of drop pipe 260 ft. capacity 800 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Tan clay with sand & gravel streaks				131	140	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co. inc. 150 Business name License No. Address box 686, Garden City Signed [Signature] Date 3 Jul 75 Authorized representative
Fine to coarse sand medium gravel				140	155	
Fine to coarse sand medium gravel, green clay				155	160	
Fine to coarse sand medium gravel				160	241	
Fine to coarse sand med. gravel, tan clay stk				241	259	
Fine to coarse sand medium gravel				259	320	
Fine to coarse sand				320	341	
Fine to coarse sand with clay streaks				341	361	
Fine to coarse sand (use a second sheet if needed)				361	379	
Remarks: elevation						
Tan clay				402	440	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5