


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Stevens	Township name	X Fraction NW	Section number 4	Town number 33	Range number 35		
Distance and direction from nearest town or city: Street address of well location if in city: Hugoton, Kansas			3 Owner of well: Dean Harmon Address: 602 Harrison St Hugoton Kansas					
Locate with "X" in section below: N  W S 1 Mile			Sketch map:			4 Well depth: 620 ft. Date of completion 3-5-76 Well diameter 16 in.		
2 Type and color of material			From		To			
			Topsoil		0 3		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			Red Sandy Clay		3 68		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			Sand & Gravel		68 81		7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 8 in. Diam. 16 in. to 620 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth Plate welded on	
			Red Sandy Clay		81 118		8 Screen: Manufacturer slotted Type _____ Dia. _____ Slot/gauze 3/16 Length _____ Set between _____ ft. and 200 ft. 620 Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2	
			White Clay		118 176		9 Static water level: 138 ft. below land surface Date 3-5-76	
			Sand & Gravel		176 212		10 Pumping level below land surfaces: 133 ft. after 6 hrs. pumping 1800 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 2500 g.p.m.	
			Brown Clay		212 278		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
			Coarse Sand		278 369		12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 8 inches above grade	
			White Clay		369 373		13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From _____ ft. to _____ ft.	
Sand & Gravel (Coarse)		373 620		14 Nearest source of possible contamination: unknown ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
Red Clay		620		15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Laguna Brothers Model number _____ HP _____ Volts _____ Length of drop pipe 240 ft. capacity 1400 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley (use a second sheet if needed)			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. SWEDESEN Drilling Co 242 Business name _____ License No. _____ Address Route 1, Gordon City Kansas Signed Bill Swearingen Date 3/13/76 Authorized representative					

33 35 W 4 NW