

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stevens	Fraction NW 1/4 NW 1/4 Sec 1/4	Section number 20	Township number T 23 S	Range number R 25 E/W																																		
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:																																					
2. Distance and direction from nearest town or city: 16 E 1/2 S of			3. Owner of well: James Schmidt																																					
Street address of well location if in city: Hugoton, Ka			R.R. or street: R.R.																																					
4. Locate with "X" in section below:			6. Bore hole dia. 10 in. Completion date 9-20-77																																					
Sketch map:			Well depth 340 ft.																																					
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug																																					
			<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																																					
5. Type and color of material			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry																																					
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>20</td> </tr> <tr> <td>20</td> <td>50</td> </tr> <tr> <td>50</td> <td>54</td> </tr> <tr> <td>54</td> <td>70</td> </tr> <tr> <td>70</td> <td>114</td> </tr> <tr> <td>114</td> <td>120</td> </tr> <tr> <td>120</td> <td>140</td> </tr> <tr> <td>140</td> <td>160</td> </tr> <tr> <td>160</td> <td>168</td> </tr> <tr> <td>168</td> <td>206</td> </tr> <tr> <td>206</td> <td>217</td> </tr> <tr> <td>217</td> <td>223</td> </tr> <tr> <td>223</td> <td>232</td> </tr> <tr> <td>232</td> <td>244</td> </tr> <tr> <td>244</td> <td>254</td> </tr> <tr> <td>254</td> <td>303</td> </tr> </tbody> </table>			From	To	0	20	20	50	50	54	54	70	70	114	114	120	120	140	140	160	160	168	168	206	206	217	217	223	223	232	232	244	244	254	254	303	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			From	To																																				
0	20																																							
20	50																																							
50	54																																							
54	70																																							
70	114																																							
114	120																																							
120	140																																							
140	160																																							
160	168																																							
168	206																																							
206	217																																							
217	223																																							
223	232																																							
232	244																																							
244	254																																							
254	303																																							
light gray to buff w/ calcic nodules sand brown to redish Clay brownish red Sand brownish red containing clays Clays gray to white to brown clay balls small w/ sand tan " shelf tan " balls w/ some calcic rock " " w/ calcic + sand coarse " " with rock stringers Sand coarse w/ fine gravel Clays w/ sand fine Sand coarse Clays w/ sand intermitently coarse Sand coarse Clay s. Tan			9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 24 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 340 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250																																					
Topsoil thin 6" light gray to buff w/ calcic nodules 0 20 sand brown to redish 20 50 Clay brownish red 50 54 Sand brownish red containing clays 54 70 Clays gray to white to brown 70 114 clay balls small w/ sand tan 114 120 " shelf tan 120 140 " balls w/ some calcic rock 140 160 " " w/ calcic + sand coarse 160 168 " " with rock stringers 168 206 Sand coarse w/ fine gravel 206 217 Clays w/ sand fine 217 223 Sand coarse 223 232 Clays w/ sand intermitently coarse 232 244 Sand coarse 244 254 Clay s. Tan 254 303			10. Screen: Manufacturer's name Slotted Type Saw cut Dia. 5 " Slot/gauze 1/8 Length 40 " Set between 236 ft. and 256 ft. 316 ft. and 336 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/16 - 1/4																																					
18. Elevation:			11. Static water level: _____ mo./day/yr.																																					
19. Remarks:			12. Pumping level below land surfaces: 150 ft. after 1 hrs. pumping 15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.																																					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																																					
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 Inches above grade																																					
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.																																					
			16. Nearest source of possible contamination: ft. 60 Direction N Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																																					
			17. Pump: _____ Not installed Manufacturer's name Flint + Walling Model number 10BA15 HP 1 Volts 230 Length of drop pipe 195 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																					
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Stevens Well Drilling 127 Business name _____ License No. _____ Address Hugoton Ka Signed Paul Stevens Date 9-28 Authorized representative																																					

33
 35
 20
 NW 1/4
 1/4 N 1/4

