

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620


1 Location of well:	County Stevens	Township name	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 22	Town number T 33 W S	Range number R 35 W
---------------------	-------------------	---------------	-------------------------------------	----------------------	-------------------------	------------------------

Distance and direction from nearest town or city:
1/2 mile West of Woods
Street address of well location if in city:

3 Owner of well: Charles Harper
Address: Route #1 Hugoton, Kansas

Locate with "X" in section below:
N

Sketch map:



4 Well depth: 375 ft. Date of completion 1-16-75
Well diameter 7/8 in.

5 Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

6 Use: Domestic Public supply Industry
 Irrigation Air conditioning Commercial
 Test well

7 Casing: Material Plastic Height: above/below
Threaded Welded Surface ±2 in.
Diam. _____ Weight _____ lbs./ft. _____
5 in. to 375 ft. depth Drive shoe? Yes No
_____ in. to _____ ft. depth!

2	Type and color of material	From	To
	See Attachment		
	Top soil	0	3
	Brown Clay, very few ledges	3	83
	Clay, brown, few broken rk & ledges, v. few s st.	83	110
	sand with clay, f. - v.c., brownish-tan, ledges and sand stringers.	110	146
	clay, brown-gray-blue, mixed, few ledges	146	173
	Clay, brownish-tan, sand st., few ledges	173	194
	Sand, f.-med., some coarse and some small gravel with some clay st., used some water	194	210
	Clay with sand, brown, stringers, f-m-coarse	210	230
	Clay, brown	230	251
	Sand, v.f.-f., with clay stringers	251	257
	Clay, brown, sticky, with very few sand stringers	257	308
	Sand, v.f., with few clay stringers	308	322
	Clay, brown, with few (use a second sheet if needed) sand stringers	322	331

8 Screen:
Manufacturer Jess & Lowell
Type Slotted Dia. 5"
Slot/gauze #060 Length 30'
Set between 345 ft. and 375 ft.
Fittings:
Gravel pack Yes No Size range of material 8-30

9 Static water level:
81 ft. below land surface Date 1-16-75

10 Pumping level below land surfaces:
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield _____ g.p.m.

11 Water sample submitted:
 Yes No Date _____

12 Well head completion:
 Pitless adapter 12 Inches above grade

13 Well grouted? Yes No
 Neat cement Bentonite _____
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination: None Observe
ft. _____ Direction _____ Type _____
Well disinfected upon completion? Yes No

15 Pump: Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.m.p.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

16 Remarks: elevation
Clay, brown, sticky, v. few sand stringers 331 358
Sand, f.-m.-c., few small gravel. drld loose 358 420
Topography: Flat
 Hill Slope Upland Valley
Total depth of well (375)

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Henkle Drilling & Supply Co 145
Business name _____ License No. _____
Address Box 639 Garden City, Ks.
Signed: *Richard Henkle* Date 1/23/75
Authorized representative