


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County STEVENS	Fraction SW 1/4 NE 1/4 NW 1/4	Section number 25	Township number 33	Range number 35
2. Distance and direction from nearest town or city: City. to 270 Jet. West to Lone Star 75-Yds. Street address of well location if in city: Church 1 south, east 75 Yds. south			3. Owner of well: Reece D. Morgan 210 N. Main Hugoton, Ks 67951 R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. <u>26</u> in. Completion date <u>3-31-76</u> Well depth <u>518</u> ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					<input checked="" type="checkbox"/> Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>519</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>250</u>
					10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>180</u> ft. and <u>500</u> ft. Perf. <u>200-180</u> ft. and <u>500-518</u> ft. Gravel pack? <u>yes</u> Size range of material <u>2 1/2" Down</u>
					11. Static water level: <u>102</u> ft. below land surface Date <u>12-22-75</u> mo./day/yr.
					12. Pumping level below land surfaces: <u>133</u> ft. after <u>2</u> hrs. pumping <u>895</u> p.m. <u>144</u> ft. after <u>4</u> hrs. pumping <u>1227</u> p.m. Estimated maximum yield <u>1200</u> g.p.m.
					13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>
					14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter
					15. Well grouted? <u>YES</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <u>Not installed</u> Manufacturer's name <u>Peerless Inc</u> Model number <u>121B</u> HP <u>125</u> Volts <u> </u> Length of drop pipe <u>240</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			(Use a second sheet if needed)		
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter Wilson Drilling, 208</u> Business name License No. <u> </u> Address <u>P. O. Box A Garden City, Ks</u> Signed <u> </u> Date <u>7-16-76</u> Authorized representative		

33 35E 25 SENEW 1/4 1/4 1/4

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Reece Morgan
Stevens County
11-4-75

Location: NW 25-33-35
Northeast Corner of $\frac{1}{4}$, East of Woods to Lone
Star Church, 1 mile South, $\frac{1}{2}$ mile East
300 feet South

Static Water Level: 135'

Test # 6

0	1	Top Soil
1	16	Sand & Clay mixed
16	35	Brown Clay
35	53	Fine to Med. Sand
53	65	Fine to Med. Sand, 15% Clay (Loose)
65	78	Fine to Med. Sand & Fine Gravel (Loose)
78	123	Fine to Med. Sand & Gravel (Loose)
123	156	Brown Clay
156	187	Brown Clay & White Rock (Tight)
187	200	Fine to Med. Sand & Gravel (Loose)
200	217	Fine to Med. Sand & Gravel, 10% Clay (Loose)
217	245	
245	260	Fine to Med. Sand & Fine Gravel, 15% Clay (Loose)
260	272	Fine to Med. Sand & Fine Gravel (Loose)
272	290	Brown Sandy Clay
290	307	Fine to Med. Sand & Gravel (Loose)
307	320	Fine to Med. Sand & Fine Gravel, 15% Clay (Loose)
320	354	Fine to Med. Sand & Fine Gravel (Loose)
354	365	Fine to Med. Sand & Fine Gravel, 10% Clay (Loose)
365	380	Fine to Med. Sand & Gravel (Loose)
380	397	Fine to Med. Sand & Fine Gravel, 10% Clay (Loose)
397	440	Fine to Med. Sand & Gravel, 10% Clay (Loose)
440	518	Fine to Med. Sand & Fine Gravel (Loose)
518	545	Brown, Gray & Yellow Clay with white Rock

TD 518'