

1 LOCATION OF WATER WELL: County: Stevens	Fraction $\frac{1}{4}$ $\frac{1}{4}$ C//se $\frac{1}{4}$	Section Number 9	Township Number T 33 S	Range Number R 36 E/W
--	---	---------------------	---------------------------	--------------------------

Distance and direction from nearest town or city street address of well if located within city?

W of Liberal to Hooker/Moscow Rd, N to Hwy, then 1N, 1W &amp; N into gate, follow fence W to well--

2 WATER WELL OWNER: John T. Townsden	Board of Agriculture, Division of Water Resources
RR#, St. Address, Box #: 514 Nancy Street	Application Number:
City, State, ZIP Code: White Hall, Ark. 71602-2981	

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: 340 ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. 100 ft. 2. ft. 3. ft.
	WELL'S STATIC WATER LEVEL: 100 ft. below land surface measured on mo/day/yr 8/24/92
	Pump test data: Well water was 170 ft. after 1 hours pumping 80 gpm
	Est. Yield 80 gpm: Well water was ft. after hours pumping gpm
	Bore Hole Diameter 9 1/2 in. to 340 ft. and in. to ft.
WELL WATER TO BE USED AS:	
<input checked="" type="radio"/> Domestic    3 Feedlot    6 Oil field water supply    9 Dewatering    12 Other (Specify below) 2 Irrigation    4 Industrial    7 Lawn and garden only    10 Monitoring well	
Was a chemical/bacteriological sample submitted to Department? Yes.....No...X.....; If yes, mo/day/yr sample was submitted	
Water Well Disinfected? Yes X No	

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued X Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)
<input checked="" type="radio"/> PVC	4 ABS	7 Fiberglass	Welded
Blank casing diameter 5 in. to 340 ft., Dia			Threaded
Casing height above land surface 24 in., weight 2,902 lbs./ft.			Wall thickness or gauge No. 280 SDR21
TYPE OF SCREEN OR PERFORATION MATERIAL:			
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS
SCREEN OR PERFORATION OPENINGS ARE:			
1 Continuous slot	3 Mill slot	5 Gauzed wrapped	<input checked="" type="radio"/> Saw cut
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes
SCREEN-PERFORATED INTERVALS:			
From 260 ft. to 340 ft., From 220 ft. to 340 ft.			
GRAVEL PACK INTERVALS:			
From 140 ft. to 340 ft., From 3.539 ft. to wall thickness			

6 GROUT MATERIAL:	<input checked="" type="radio"/> Neat cement	2 Cement grout	3 Bentonite	<input checked="" type="radio"/> Other Hole Plug
Grout intervals: From 1 ft. to 20 ft., From ft. to ft., From ft. to ft.				
What is the nearest source of possible contamination:				
1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
Direction from well? How many feet?				

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	Surface Soil			
2	6	Caliche			
6	100	Sand			
100	160	Clay			
160	181	Sand			
181	203	Clay			
203	225	Sand			
225	233	Clay			
233	248	Clay & Sand Streaks			
248	266	Red Clay			
266	274	Sand & Clay Streaks			
274	334	Sand			
334	340	Sand & Clay Streaks			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <input checked="" type="radio"/> constructed, <input type="radio"/> reconstructed, or <input type="radio"/> plugged under my jurisdiction and was completed on (mo/day/year) 8/22/92 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. KWWCL-430. This Water Well Record was completed on (mo/day/yr) 8/22/92 under the business name of Howard Drlg Co, Box 806 Beaver, OK 73932 by (signature)
--

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.