


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>STerens</u>	Township name <u>NE 1/4 NE 1/4 SW 1/4</u>	Fraction <u>15</u>	Section number <u>15</u>	Town number <u>T33 S</u>	Range number <u>R37 W</u>
Distance and direction from nearest town or city: <u>1/2 E of HUGOTON</u>			3 Owner of well: <u>Mr. Bur Cox and Ringit Cox</u>			
Street address of well location if in city:			Address: <u>HUGOTON, Kansas 67451</u>			
Locate with "X" in section below: N  S 1 Mile			Sketch map:			
2 Type and color of material			From	To	4 Well depth: <u>220</u> ft. Date of completion <u>8-1-75</u> Well diameter <u>10</u> in.	
<u>silty Gray</u>			<u>1</u>	<u>10</u>	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<u>sand fine redish</u>			<u>10</u>	<u>40</u>	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
<u>sand coarse tan some gravel</u>			<u>40</u>	<u>85</u>	7 Casing: Material <u>PRC</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Diam. <u>6</u> in. to <u>5</u> ft. depth Weight <u>2.34</u> lbs./ft. <u>1</u> <u>5</u> in. to <u>220</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
<u>clay balls containing some gravel</u>			<u>85</u>	<u>92</u>	8 Screen: <u>saw slot</u> Manufacturer <u>Pumpco</u> Type <u>Polyvinyl Chloride</u> <u>5</u> Slot/gauze <u>1/8</u> Length <u>40</u> Set between <u>160</u> ft. and <u>220</u> ft. Fittings: <u>1/4 to 3/16</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>—</u>	
<u>caliche white limy w/ some gravel</u>			<u>92</u>	<u>114</u>	9 Static water level: <u>83</u> ft. below land surface Date <u>8-1-75</u>	
<u>shale shelf Green cast in collar</u>			<u>114</u>	<u>123</u>	10 Pumping level below land surfaces: <u>90</u> ft. after <u>1</u> hrs. pumping <u>70</u> g.p.m. <u>—</u> ft. after <u>—</u> hrs. pumping <u>—</u> g.p.m. Estimated maximum yield <u>200</u> g.p.m.	
<u>caliche soft w/ caliche stringers hard</u>			<u>123</u>	<u>146</u>	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>—</u>	
<u>clay shelf brown</u>			<u>146</u>	<u>160</u>	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
<u>clay balls brown + sand fine to coarse</u>			<u>160</u>	<u>176</u>	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Cement Depth: From <u>3</u> ft. to <u>13</u> ft.	
<u>clay shelf " some joint clay</u>			<u>176</u>	<u>197</u>	14 Nearest source of possible contamination: ft. <u>100</u> Direction <u>South</u> Type <u>Septic Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<u>clay balls w/ coarse sand brown + tip rock</u>			<u>197</u>	<u>200</u>	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Aermotor</u> Model number <u>SE50-500</u> HP <u>15</u> Volts <u>230</u> Length of drop pipe <u>168</u> ft. capacity <u>20</u> g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
<u>" " w/ coarse sand brown</u>			<u>200</u>	<u>205</u>		
<u>sand coarse + fine gravel brown</u>			<u>205</u>	<u>220</u>		
<u>clay + silt tan</u>			<u>220</u>	<u>240</u>		
(use a second sheet if needed)						
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Stacum well Drilling</u> Business name <u>HUGOTON</u> License No. <u>127</u> Address <u>Kansas</u> Signed <u>Paul Stacum</u> Date <u>8-20-75</u> Authorized representative			