

[illegible]

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

City of Hugoton
Stevens County
9-24-87

Location: SW NE $\frac{1}{4}$ 16-33-37
1 $\frac{1}{2}$ Blocks north of city office
east of road

Static Water Level - 116'

Test #1

0	4	Top soil	
4	22	Brown clay (Lost circulation 20')	Ø1
22	27	Brown sandy clay	Ø4
27	74	Fine sand - tight	Ø7
74	80	Fine to medium sand & gravel	17
80	97	Fine sand - tight	Ø7
97	115	White clay - hard	Ø1
115	128	White clay - brown rock - hard	28
128	140	Brown clay	Ø1

140' Well
5" PVC
7-7/8" Hole
90' Plain
50' Perf.
1 Yd. Gravel

Marks: City of Hugoton Well #3