USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section	number	Township number Range number	
1. Location of well:	Stevens		C-SE	1	.0	T 33 S R 38 E/W	
2. Distance and direction from nearest town or city: $4\frac{1}{4}$ West of 3. Own					ner of well Anadarko Production Co.		
Hugoton & north to loc.  R.R. or street: P. (							
City, state, zip code:					Liberal, Kansas 67901		
4. Locate with "X" in section below:  Sketch map:						6. Bore hole dia9_ in. Completion date 2_28_77  Well depth220_ft	
Ŧ ŢŢŢŢ						7 Cable tool X Rotary _ Driven _ Dug	
- NW NE - Doeating 15.56						Hollow rod Jetted Bored Reverse rotary	
						8. Use: Domestic Public supply Industry	
W Ville Ville						Irrigation Air conditioning Stock Lawn Oil field water Other	
sw   <b>3</b>						9. Casing: Material Height: Above or below	
						Threaded WeldediSurface 28in.	
S 1 Mile					RMP PVC X Weight 2.78 lbs./ft.		
5. Type and color of material				From	То	Dia. 5 in. to 120 depth Wall Thickness: inches or Dia. 5 in. to 220 depth gage No. 265	
						10. Screen: Manufacturer's name	
Surface				0	2	Type PVC Dig. 5 !!	
Clay				2	20	Slot/gauze Length	
				20		ft and ft.	
Fine sand				20	60	orarer pack; orac range or marerial	
Gravel and sandy clay 60-40				60	80	11. Static water level:	
Med. to large sand				80	210	12. Pumping level below land surfaces:	
				0.7.0	200	ft. after hrs. pumping g.p.m.  ft. after hrs. pumping g.p.m.	
Sandy cla	У			210	220	Estimated maximum yieldg.p.m.	
				ļ	ļ	13. Water sample submitted: mo./day/yr.  Yes X No Date	
						14. Well head completion:	
						Pitless adapter	
				<u> </u>	<del>                                     </del>	15. Well grouted? <u>Ves</u>	
					<u> </u>	With: X Neat cementBentonite Concrete Concrete Bentonite Bentonite Concrete Bentonite	
						16. Negrest source of possible contamination:  ft. 100 Direction NE Type oilwell	
						Well disinfected upon completion? X Yes No. 10	
						17. Pump: X Not installed	
				+		Manufacturer's name HP Volts	
						Length of drop pipe ft. capacityg.p.m.	
						Type: Submersible Turbine	
						Jet Reciprocating	
	(Use a second s	heet if needed)			-	CentrifugalOther	
18. Elevation:	19. Remarks:					20. Water well contractor's certification:  This well was drilled under my jurisdiction and this report	
						is true to the best of my knowledge and belief.	
Topography:						Carlile Water Well 118	
Slope						Address Box 2/5, Liberal, Ks.	
X Upland						Signed Authorized representative	
Valley	L						