

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stevens	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 11	Township number T 33 S R 39 E/W	Range number																																							
2. Distance and direction from nearest town or city: 10 W, 1/2 N, from North edge of Hugoton, Kansas. Street address of well location if in city:				3. Owner of well: Sam Bazone R.R. or street: R. R. City, state, zip code: Rolla, Kansas																																									
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 10px;"> <p>Sketch map:</p> </div> <div> <p>NE corner of the SW 1/4, Sec. 11, T33S, R39W, Stevens County, Kansas.</p> </div> </div>				6. Bore hole dia. 28 in. Completion date 10/9/76 Well depth 342 ft.																																									
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																																									
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																																									
				9. Casing: Material stl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 192 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219																																									
				10. Screen: Manufacturer's name Foster, Johnson Type WW, millslot Dia. 16" Slot/gauze 1/8" Length 150' Set between 192 ft. and 342 ft. Gravel pack? yes Size range of material 3.0mm																																									
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:60%;"></th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr><td>Fine sand</td><td>0</td><td>9</td></tr> <tr><td>Sandy clay</td><td>9</td><td>20</td></tr> <tr><td>Fine sand</td><td>20</td><td>28</td></tr> <tr><td>Coarse sand and gravel</td><td>28</td><td>46</td></tr> <tr><td>Sand with clay streaks</td><td>46</td><td>69</td></tr> <tr><td>Mixed colored clay</td><td>69</td><td>198</td></tr> <tr><td>Coarse sand with clay streaks</td><td>198</td><td>232</td></tr> <tr><td>Clay with sand streaks</td><td>232</td><td>258</td></tr> <tr><td>Coarse sand fine to medium gravel</td><td>258</td><td>318</td></tr> <tr><td>Tan clay with cemented sand streaks</td><td>318</td><td>342</td></tr> <tr><td>Yellow sandy clay</td><td>342</td><td>376</td></tr> <tr><td>Red bed</td><td>376</td><td>420</td></tr> </tbody> </table>					From	To	Fine sand	0	9	Sandy clay	9	20	Fine sand	20	28	Coarse sand and gravel	28	46	Sand with clay streaks	46	69	Mixed colored clay	69	198	Coarse sand with clay streaks	198	232	Clay with sand streaks	232	258	Coarse sand fine to medium gravel	258	318	Tan clay with cemented sand streaks	318	342	Yellow sandy clay	342	376	Red bed	376	420	11. Static water level: 112 ft. below land surface Date 5/17/76 mo./day/yr.		
					From	To																																							
				Fine sand	0	9																																							
				Sandy clay	9	20																																							
				Fine sand	20	28																																							
				Coarse sand and gravel	28	46																																							
				Sand with clay streaks	46	69																																							
				Mixed colored clay	69	198																																							
				Coarse sand with clay streaks	198	232																																							
				Clay with sand streaks	232	258																																							
Coarse sand fine to medium gravel	258	318																																											
Tan clay with cemented sand streaks	318	342																																											
Yellow sandy clay	342	376																																											
Red bed	376	420																																											
12. Pumping level below land surfaces: 224 ft. after 1/2 hrs. pumping 1812 g.p.m. 230 ft. after 1 hrs. pumping 1710 g.p.m. Estimated maximum yield 1750 g.p.m.																																													
13. Water sample submitted: xx Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date																																													
14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <input type="checkbox"/> Inches above grade																																													
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																																													
16. Nearest source of possible contamination: unk ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																																													
17. Pump: Manufacturer's name Layne & Bowler Not installed Model number 12 KM HP 125 Volts Length of drop pipe 280 ft. capacity 950 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																													
(Use a second sheet if needed)																																													
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name License No. Address Garden City, Kansas Signed <i>[Signature]</i> Date 1/26/76 Authorized representative																																									
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley																																													

33
 39
 11
 NE
 1/4
 1/4
 1/4
 1/4