


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stevens	Fraction NW 1/4 NE 1/4 Sec 26	Section number 26	Township number T 33 S	Range number R 39 E	
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: R. S. Buddenberg R.R. or street: Rt. 1 City, state, zip code: Gothenburg, Nebraska 69138			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 3 1/2 in. Completion date 5/24/77 Well depth 444 ft.			
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Overburden		0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Top Soil & Caly		2	140	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42.5 lbs./ft.			
Clay		140	220	Dia. 4 1/2 in. to 4 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1250			
Fine Sd. & Clay		220	240	10. Screen: Manufacturer's name L B Foster Type Steel Dia. 1 1/2 " Slot/gauze VB Length 3 Set between 198-270 ft. and 280-380 ft. 400-444 ft. and 4 ft.			
Med. Sd. & Clay		240	260	Gravel pack? <input checked="" type="checkbox"/> Size range of material VB-1/4			
Med. to Coarse Sd. & Clay Strks.		260	340	11. Static water level: <input type="checkbox"/> mo./day/yr. 101 ft. below land surface Date 5/24/77			
Med. Sd. & Clay		340	380	12. Pumping level below land surfaces: 74 ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
Med. Sd. Gravel, Clay & Rock		380	400	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____			
Sand Gravel Rock & Red Bed		400	440	14. Well head completion: ____ Pitless adapter NA ____ Inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
				16. Nearest source of possible contamination: ft. ____ Direction ____ Type Field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KTM DRILLING, INC. 225 Business name License No. Address Box 1385, Guyman, Okla. Signature James Stuber Date 5/24/77 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		10A Johnson FRR 16" Steel 11000 Slot 270-280 380-400 16A Crop Land					