

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CWW Inv. #14127

Sheets A-1

1. Location of well:		County Stevens	Fraction 2570' FSL 1250' FEL 1/4 1/4 1/4	Section number 35	Township number T 33S S R 39W E/W	Range number
2. Distance and direction from nearest town or city: From Feterita go 2m West - 1m South- West to location			3. Owner of well: Rains & Williamson Oil Co. R.R. or street: 435 Page Court 220W. Douglas City, state, zip code: Wichita, Kansas 67202			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: <i>2mi. West Feterita</i> <i>X West to loc.</i>		6. Bore hole dia. 9 in. Completion date 12-21 Well depth 300 ft.		
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface		0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Medium to large sand		2	45	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.78 lbs./ft. Dia. 5 in. to 175 ft. depth Wall Thickness: inches or Dia. 5 in. to 300 ft. depth gage No. 265		
Gravel & Sandy clay 40-60		45	60	10. Screen: Manufacturer's name Sawed Perf. Type PVC Dia. 5 in. Slot/gauze .030 Length 100 ft. Set between 175 ft. and 275 ft. ft. and ft. Gravel pack? yes Size range of material 1/8-3/16		
Sandy clay		60	160	11. Static water level: 130 ft. below land surface Date 12-21-77 mo./day/yr.		
Brown Clay		160	200	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50 g.p.m.		
Medium to large sand & sandy clay 70-30		200	260	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 12-21-77 mo./day/yr.		
Medium to large sand & blue sandy clay				14. Well head completion: 28 inches above grade Pitless adapter		
20-80		260	280	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Blue clay		280	300	16. Nearest source of possible contamination: ft. 100 Direction NE Type oil well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name License No. Address Box 275, Liberal, KS Signed Edward E. Means Date 1-6-78 Authorized representative		

(Use a second sheet if needed)