


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County MORTON	Township name WESTOLA	Fraction NWNE 1/4	Section number 17	Town number 33	Range number 42
Distance and direction from nearest town or city: 13N 12W EKART-KANS. Street address of well location if in city:				3 Owner of well: W.C. OREVALENA Riley Address: ELKHART-KANS. 67950 Box 795			
Locate with "X" in section below:		Sketch map:		4 Well depth: 547 ft. Date of completion: NOV 18-75 Well diameter 19 in.			
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well			
				7 Casing: Material 219 Height: above <input checked="" type="checkbox"/> below <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. Diam. 16 in. to 28 1/2 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 14 in. to 547 ft. depth			
2 Top-Clay & Gyp Rock		Type and color of material	From	To	8 Screen: Manufacturer _____ Type _____ Dia. _____ Slot/gauze 1/4" cut Length 88 Set between 196 ft. and 284 ft. 547 Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/4" Rock		
SAND Coarse & Clay Stks			0	83	9 Static water level: 70 ft. below land surface Date NOV 18-75		
SANDY Clay & Red Clay			83	100	10 Pumping level below land surfaces: 380 ft. after 12 hrs. pumping 790 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 790 g.p.m.		
TAN S.R. Red Clay Stks Red S.R. Stks			100	190	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Red S.R. Red Clay Stks			190	320	12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Red S.R. Broken Red Clay Stks			320	510	13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 196 ft. to 10 ft. Below Ground		
Red SHALE			510	535	14 Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
			535	547	15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
					16 Remarks: elevation		
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Edith's Irrigation Drilling Co. INC. Business name _____ License No. 154A Address 1300 S. MAIN Signed Edith R. Woods Date _____ Authorized representative Springfield, Colo. 81073		
					Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		