


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County MORTON	Township name WESTOLA	Fraction NWSE 1/4	Section number 3	Town number 33	Range number 43
Distance and direction from nearest town or city: 13N 3W 12N 1/2W ELKHART-KANS. 67950				3 Owner of well: PRENTICE Soupiset Address: ELKHART-KANS. 67950		
Locate with "X" in section below: N  W E S 1 Mile		Sketch map:		4 Well depth: 340 ft. Date of completion 10-20-75 Well diameter 19 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
Top Soil / Clay Gyp Gyp Rock & Clay Clay & Sandy Clay Coarse Sand & Clay Stks Sand & Clay Stks Tan S.R. & Brown Rock Stks Red Clay & Green Clay Stks Silty S.R. & Clay Tan S.R. Clean Drilling Good Using Water Yel.-Tan S.R. Clean Tan S.R. Clean h.c. 250-260 Red S.R. Red Clay Stks Red-Tan S.R. Drilled Good & Clean				7 Casing: Material 219 Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. Diam. 16 in. to 14 1/2 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 14 in. to 340 ft. depth		
				8 Screen: Manufacturer _____ Type _____ Dia. _____ Slot/gauze 1/4 cut Length 75 Set between 75 ft. and 145 ft. 340 Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material _____		
(use a second sheet if needed)				9 Static water level: 81 ft. below land surface Date 10-20-75		
				10 Pumping level below land surfaces: 180 ft. after 12 hrs. pumping 1100 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1100 g.p.m.		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 19 Above 19 ft. Below Ground		
				14 Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ralph's Irrigation Drilling Center Business name _____ License No. 1244 Address 1300 S. MAIN Signed Calvin E. Woods Date _____ Authorized representative Springfield Mo. 65803		