

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Morton	Fraction SP NE 1/4 NE 1/4 NE 1/4	Section number 34	Township number T 33	Range number S R 43 E (W)			
2. Distance and direction from nearest town or city: 9 miles North 4 West of Elkhart, KS Street address of well location if in city:				3. Owner of well: W. D. Fletcher R.R. or street: City, state, zip code: Elkhart Kansas 67950					
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map:		6. Bore hole dia. 9 in. Completion date 10/28/75 Well depth 190 ft.					
<table border="1"><tr><td>NW</td><td>NE</td></tr><tr><td>SW</td><td>SE</td></tr></table>		NW	NE	SW	SE	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		NW	NE						
		SW	SE						
		9. Casing: Material PHS. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 130 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 320		10. Screen: Manufacturer's name J+L Type RMP Dia. 5" Slot/gauze 1/16 Length 60 Set between 130 ft. and 190 ft. Gravel pack? Yes Size range of material 18					
11. Static water level: <input type="checkbox"/> mo./day/yr. 126 ft. below land surface Date 10/28/75		12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 25 g.p.m.		13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date					
14. Well head completion: ____ Pitless adapter 14" Inches above grade		15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		16. Nearest source of possible contamination: ft. 400 Direction NW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		18. Elevation:		19. Remarks: Well to be Completed by: H.P. Steele Water Well Service Elkhart, KS.					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+W Water Well 142 Business name License No. Address PO Box 816 Elkhart, KS. Signed C. D. Wagonmiller Date 10/28/75 Authorized representative		33 43 34 SE NE NE							