

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Gomenche	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 17	Township number T 34 S R 20 W E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: Joe Schumacher, R.R. or street: City, state, zip code: Protection, Ks. 67127		
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 8.75 in. Completion date _____ Well depth 44.5 ft. 10-22-79		
				7. <input checked="" type="checkbox"/> Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary		
				8. Use: ___ Domestic ___ Public supply ___ Industry ___ Irrigation ___ Air conditioning <input checked="" type="checkbox"/> Stock ___ Lawn ___ Oil field water ___ Other		
5. Type and color of material				From	To	9. Casing: Material _____ Height: Above or below
Black clay topsoil				0	5	Threaded ___ Welded _____ Surface 15 above in.
Red clay with gravel mixed				5	43	RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft.
Gyp rock				43	44.5	Dia. 5 in. to 44.5 ft. depth Wall Thickness _____ inches or Dia. _____ in. to _____ ft. depth gage No. .250
						10. Screen: Manufacturer's name Jess & Lowell
						Type Rmp Dia. 5
						Slot/gauze saw Length 10 ft.
						Set between 34.5 ft. and 44.5 ft.
						Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/16-3/4
						11. Static water level: 15 ft. below land surface Date 10-22-79
						12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 12 g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
						14. Well head completion: ___ Pitless adapter 24 inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> yes With: ___ Neoprene ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.
						16. Nearest source of possible contamination: ft. none Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> yes Yes <input checked="" type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: ___ Submersible _____ Turbine ___ Jet _____ Reciprocating ___ Centrifugal _____ Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:			20. Water well contractor's certification:	
Topography: ___ Hill <input checked="" type="checkbox"/> Slope ___ Upland ___ Valley		Hole was dry at 43 and filled to 15 ft. when into the rock. 65/8 iron pipe set in concrete to hold pump and protect casing.			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Wymer Blacksmith Shop 228 Business name License No. Address box 172 Protection Ks. Signed Kenneth L Wymer Date 11-4-79 Authorized representative	

T 34
 R 20
 W E/W
 Sec 17
 1/4 SW
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5