

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

TROUT CREEK

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

CWW Inv. #12960

1. Location of well:		County Clark	Fraction 1/4C-NE1/4 NE 1/4	Section number 21	Township number T 34 S R 21 E/W	Range number 21 E/W
2. Distance and direction from nearest town or city: on Hwy. 160 about 6 mi. to Sitka Jct. then 3 mi. So. - 3/4 mi. ea. - 5 1/4 mi. So. to No.			3. Owner of well: Sage Drilling Co. R.R. or street: 500 Biting Bldg. City, state, zip code: Wichita, KS 67202			
4. Locate with "X" in section below:		Sketch map: side of River Bridge then follow Lease rd. 1 3/4 mi. Ea. to loct.		Bore hole dia. 9 in. Completion date 12/9-76 Well depth 40 ft.		
		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface 28 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.78 lbs./ft. Dia. 5 in. to 5 ft. depth Wall Thickness: _____ inches or Dia. 5 in. to 40 ft. depth gage No. 265				
5. Type and color of material		From	To	10. Screen: Manufacturer's name _____ Sawed perf. Type PVC Dia. 5 1/2 Slot/gauze .030 Length 30' Set between 5 ft. and 35 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/8-3/16		
Surface		0	2	11. Static water level: _____ mo./day/yr. 4 ft. below land surface Date 12/9/76		
Med. to lge. sand & gravel		2	30	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping 60 g.p.m. Estimated maximum yield 60 g.p.m.		
Sandy clay & redbed		30	40	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
NOT TO BLOCK				14. Well head completion: _____ Pitless adapter _____ 28 Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 100 Direction NE Type oilwell Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
(Use a second sheet if needed)				18. Elevation:		
19. Remarks:		1765 <input checked="" type="checkbox"/> Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well Ser. 118 Business name _____ License No. _____ Address Box 275, Liberal, KS Signed Edward E Means Date 1-2-77 Authorized representative				

34 210 21 C NE NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5