

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

3423W/11C
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg, 740
Topeka, Kansas 66620

B B D

1 Location of well:	County CLARK	Township name X	Fraction SE NW NW	Section number 11	Town number T 34 S	Range number R 23 W
Distance and direction from nearest town or city: OF Ashland Co. 6.50 1 W 1/8 SE			3 Owner of well: GLENN M. DUNNE 250 OLIVE GARVEY BLDG. WICHITA Ks.			
Locate with "X" in section below:		Sketch map:		4 Well depth: 100 ft. Date of completion 8/21/75 Well diameter 9" Hole 5" casing		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. Diam: 6 1/2 in. Weight 200 lbs./ft. 5" in. to 100 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
2	Type and color of material	From	To	8 Screen: PVC SAVED Manufacturer CANTEX Type 200 PSI Dia. 5" Slot/gauze 1/16 Length 60 FT Set between 40 ft. and 100 ft. Fittings: Balled collars Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8"		
	Surface	0	2	9 Static water level: 10 ft. below land surface Date 8/21/75		
	Small Gravel	2	95	10 Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 100 g.p.m.		
	Red Bed.	95	105	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter 18" inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 5 ft. to 15 ft.		
				14 Nearest source of possible contamination: No ft. Visible Contamination Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation				17 Water well contractor's certification: 239		
Mr Dunn Well Run Slab. Well Was Grouted From 5' TO 15' in case Mr. Dunn Chooses TO use PITless Adapter.				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CRAIG WATERWELL #239 Business name License No. Address Box 521 Woodward OK Signed [Signature] Date 8/21/75 Authorized representative		

34 23W 11
CRAIG W

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5