

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82051201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: <u>Meade</u>		Section number: <u>10</u>		Township number: <u>34</u>		Range number: <u>26</u>	
2. Distance and direction from nearest town or city: <u>4 E 185 of Fowler</u>				3. Owner of well: <u>Dave Wilson</u>					
Street address of well location if in city:				City, state, zip code: <u>Meade, Kansas</u>					
4. Locate with "X" in section below:				Sketch map:		6. Bore hole dia. <u>8 1/2</u> in. Completion date <u>2-20-79</u>			
						Well depth <u>77</u> ft.			
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
						9. Casing: Material <u>PVC</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>200</u> lbs./ft. Dia. <u>5</u> in. to <u>77</u> ft. depth Wall thickness: inches or Dia. <u>5</u> in. to <u>77</u> ft. depth gage No. <u>40 Sch 40</u>			
5. Type and color of material				From To		10. Screen: Manufacturer's name <u>Jet Stream</u>			
						Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>5/16"</u> Length <u>30'</u> Set between <u>47</u> ft. and <u>77</u> ft. Gravel pack? <u>Yes</u> Size of material <u>1/4" - 1/2"</u>			
<u>topsoil</u> <u>fine sand</u> <u>blue clay</u> <u>sand + clay</u> <u>sand and red clay</u>				<u>0</u> <u>5</u> <u>6</u> <u>30</u> <u>31</u> <u>50</u> <u>51</u> <u>59</u> <u>60</u> <u>77</u>		11. Static water level: <u>39</u> ft. below land surface Date <u>2/20/79</u>			
						12. Pumping level below land surfaces: <u>39</u> ft. after <u>1 1/2</u> hrs. pumping <u>30</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>30</u> g.p.m.			
						13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>			
						14. Well head completion: <u>see #19</u> <u> </u> Pitless adapter <u>24</u> inches above grade			
						15. Well grouted? <u> </u> With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u> </u> ft. to <u> </u> ft. <u>see #19</u>			
						16. Nearest source of possible contamination: ft. <u>500</u> Direction <u>S</u> Type <u>Creek bed</u> Well disinfected upon completion? <u> </u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			
						17. Pump: <u>see #19</u> <u> </u> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <input checked="" type="checkbox"/> Other			
						18. Elevation: <u> </u>			
19. Remarks: <u>Windmill Stock well #17 + #14</u> <u>4x4' cement base around well #15</u> <u>1-15 puddled clay</u>						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Bertel Del</u> <u>101 A</u> Business name <u>Meade Co</u> License No. <u> </u> Address <u> </u> Signed <u> </u> Authorized representative Date <u>2-21-</u>			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5