## PERMIT #T-78-122

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)

Nolting #1-17 Topeka, Kansas 66620 CWW Inv. #14757 County Fraction Section number Township number Range number 1. Location of well: Meade NW 1/4 NE 1/4 SE 1/4 17 **34**S Т E/W From Meade Lake 3. Owner of well: Sage Drilling Company 2. Distance and direction from nearest town or city: go South on Hwy 23 to Gas Plant then lm West R.R. or street: 222 Sutton Place
Street address of well location if in city: 3m North & West to location, state, zip code: Wichita, Kansas 67202 WENDELK. 6. Bore hole dia. 9 in. Completion date 6-24-78 4. Locate with "X" in section below: Sketch map: Well depth \_\_280ft. Ν 7. \_\_ Cable tool \_\_ Rotary \_\_ Driven \_\_ Dug \_\_ Hollow rod \_\_ Jetted \_\_\_ Bored \_\_ Reverse rotary NW NE --8. Use: \_\_\_ Domestic \_\_\_ Public supply \_\_\_XIndustry Σ W \_\_ Irrigation \_\_ Air conditioning \_\_ Stock \_\_ Lawn \_\_ Oil field water \_\_ Other 9. Casing: Material \_\_\_\_\_ Height: Above or below Threaded \_\_\_\_\_ Welded \_\_\_\_\_ iSurface \_\_\_\_ RMP\_\_\_\_\_ PVC \_\_\_\_ Weight \_\_2\_78\_ ibs./ft. Dia. 5 in. to 155 ft. depth Wall Thickness: inches or Dia. 5 in. to 280 ft. depth gage No. \_\_265 - 1 Mile 5. Type and color of material From 10. Screen: Manufacturer's name Sawed perf. 0 2 Surface Туре \_\_\_\_\_РУС\_\_\_ \_\_ Dia.\_ Slot/gauze \_\_\_\_ 2 Fine sand 20 155 ft. and 255 Set between \_\_\_\_ \_ft. and \_ Clay 20 165 Gravel pack? Yes Size range of material/8-3/16 11. Static water level: mo./day/yr. Fine sand & medium to large sand 70-30 165 190 120ft. below land surface Date 6-24-78 Medium to large sand & sandy clay 70-30 190 210 12. Pumping level below land surfaces: \_\_\_\_\_ ft. after \_\_\_\_\_ hrs. pumping \_ \_\_ ft.after \_\_\_ \_\_ hrs. pumping \_ Medium to large sand & blue sandy clay 60-40 210 240 Estimated maximum yield \_ \_g.p.m. Sandy clay 240 260 13. Water sample submitted: mo./day/yr. \_\_ Yes \_**x**\_ No Date Sandy clay 260 280 14. Well head completion: \_\_\_ Pitless adapter \_\_\_ 28 Inches above grade 15. Well grouted? yes With: X Neat cement \_ Bentonite \_\_\_ Depth: From \_\_\_\_\_\_ ft. to \_\_\_\_\_ ft. 16. Nearest source of possible contamination: ft. \_\_\_\_100 Direction \_\_\_\_ Type \_\_\_\_\_ Type \_\_\_\_\_No ■ Not installed Manufacturer's name \_ Model number \_\_\_\_\_ \_\_ HP \_\_\_\_ \_ Volts \_\_ ft. capacity \_\_\_\_\_g.p.m. Type: \_\_\_\_ Submersible Turbine \_\_\_\_ Jet Reciprocating (Use a second sheet if needed) Centrifugal Other 19. Remarks: 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. :25 Topography: <u>Carlile water Well Service 118</u>

Hill

X Upland

Slope

Valley

Address Box AA, Liberal

Signed Edward & Means Date 6-29.

Authorized representative

License No.

Kansas

W

U