

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County MEADE	Fraction CENTER 1/4 1/4 50 1/4	Section number 5	Township number T 34 S R 30 E W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:		WENDELL FOX 611 Indiana PLAINS, KANSAS 67869	
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. 3 1/2 in. Completion date 1-7-76 Well depth 369 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top Soil			0	91	9. Casing: Material SPL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 169 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219	
F to C SAND TAN CLAY			91	121	10. Screen: Manufacturer's name W.A. BEAMAN Type PUNCHER Dia. <input type="checkbox"/> Slot/gauze 6/32 Length 200 Set between 169 ft. and 369 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4/16 to 1/2" DOWN	
F to C SAND TAN CLAY			121	151	11. Static water level: <input type="checkbox"/> mo./day/yr. 165 ft. below land surface Date 1-9-76	
F to C SAND TAN CLAY			151	171	12. Pumping level below land surfaces: 210 ft. after 2 hrs. pumping 1200 g.p.m. 210 ft. after 4 hrs. pumping 800 g.p.m. Estimated maximum yield 1500 g.p.m.	
F to C SAND TAN CLAY			171	200	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
F to C SAND TAN CLAY			200	230	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
" TAN CLAY			230	352	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name BEAMAN Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. TRAVIS DRILLING 257 Business name License No. Address Box 107 LIBERAL, KS. Signed M. J. Jones Date 3-11-76 Authorized representative	
18. Elevation:		19. Remarks: Customer poured slabs		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 34
 R 30
 W
 S
 E
 1/4
 1/4
 1/4
 1/4