



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Meade	Township name	Fraction C NW SE	Section number 31	Town number 34S	Range number 30W				
Distance and direction from nearest town or city: 15 miles south of Plains, 3 1/4 West and 1/4 north				3 Owner of well: Sage Drilling Company						
Street address of well location if in city:				Address: 500 Bitting Bldg., Wichita, Kans.						
Locate with "X" in section below:		Sketch map:		4 Well depth: 160 ft. Date of completion 8-4-75 Well diameter 9 in.						
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary						
2		Type and color of material		From		To		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> Oil Rig		
								7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 28 in. Digm. 5 in. to 120 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 160 ft. depth		
								8 Screen: Manufacturer sawed perf. Type PVC Dia. 5 Slot/gauze .030 Length 30 Set between 120 ft. and 150 ft. Fittings: 1/8 - 3/16 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
								9 Static water level: 37 ft. below land surface Date 8-4-75		
								10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 60 g.p.m.		
								11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
								12 Well head completion: <input type="checkbox"/> Pitless adapter 28 inches above grade		
								13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
								14 Nearest source of possible contamination: ft. 100 Direction SE Type Oil Well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
								15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation								17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name Box 275, Liberal, KS. License No. Address Edward P. Meade Date 8-14-75 Signed Edward P. Meade Authorized representative		