

USE TYPEWRITER OR BALL-POINT PEN-PRESS FIRMLY. PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: SEWARD	Fraction: NE 1/4 NW 1/4 SW 1/4	Section number: 16	Township number: T 34	Range number: S R 32 E 10
2. Distance and direction from nearest town or city: .5 S, .25 W of Hane			3. Owner of well: BILLY D. RIGGS R.R. or street: 1120 N. WESTERN City, state, zip code: LIBERAL, KANSAS 67901			
4. Locate with "X" in section below:		Sketch map: future Planned		6. Bore hole dia. 8 1/2 in. Completion date 6-28-76 Well depth 300 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	3	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 300 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 0-320		
Sand, very fine with silt		3	82	10. Screen: Manufacturer's name Pearless Plastics Inc. Type <input type="checkbox"/> Dia. 5 in. <input checked="" type="checkbox"/> Slotted gauze .06 (1/16) Length 40 FT Set between 260 ft. and 300 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 4 to 6		
Clay, light brown		82	103	11. Static water level: <input type="checkbox"/> mo./day/yr. 193 ft. below land surface Date 6-28-76		
Sand, fine with clay		103	118	12. Pumping level below land surfaces: 237 ft. after 2 hrs. pumping 30 g.p.m. 214 ft. after 6 hrs. pumping 30 g.p.m. Estimated maximum yield 95 g.p.m.		
Limestone		118	124	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
fine sand & clay		124	182	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> _____ inches above grade		
Limestone hard		182	191	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
Sand, coarse		191	213	16. Nearest source of possible contamination: ft. 200 Direction N-NE Type SURE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Limestone stra.		213	250	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 13 EN HP 1 1/2 Volts 230 Length of drop pipe 231 ft. capacity 25 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Coarse sand with clay stricks		250	300	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name _____ License No. _____ Address _____ Signed _____ Date _____ Authorized representative _____		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Well completed by Landowner Billy D. Riggs DWB 2-28-77				

T 34 R 32 E 10
 Sec 16 NE NW SW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5