


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>Seward</u>	Township name	Fraction <u>SE 1/4, SE 1/4, NE 1/4</u>	Section number <u>35</u>	Town number <u>T34 S</u>	Range number <u>R32 W</u>		
Distance and direction from nearest town or city: <u>9 E of Liberal</u>			3 Owner of well: <u>Neil S. Hays</u>					
Street address of well location if in city:			Address: <u>Liberal, Kansas</u>					
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: <u>260</u> ft. Date of completion <u>4-12-75</u> Well diameter <u>10</u> in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			<u>Top soil dark</u>		<u>0</u>	<u>2</u>	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			<u>Redish silt</u>		<u>2</u>	<u>40</u>	7 Casing: Material <u>PRC</u> Height: <u>Above</u> below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>18</u> in. Diam. <u>5</u> in. to <u>260</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>5</u> in. to <u>260</u> ft. depth	
			<u>Caliche rock hard white to tan</u>		<u>40</u>	<u>44</u>	8 Screen: <u>sawed</u> Manufacturer <u>Pumpco</u> Type <u>Polyvinyl Chloride</u> Dia. <u>5"</u> Slot/gauze <u>1/4</u> Length <u>20'</u> Set between <u>340</u> ft. and <u>360</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/4" - 1/8"</u>	
			<u>" soft + hard Mixed</u>		<u>44</u>	<u>80</u>	9 Static water level: <u>190</u> ft. below land surface Date <u>4-12-75</u>	
			<u>Coarse sand + fine Gravel some clay balls</u>		<u>80</u>	<u>140</u>	10 Pumping level below land surfaces: <u>191</u> ft. after <u>1</u> hrs. pumping <u>16</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.	
			<u>Sand brown + fine</u>		<u>140</u>	<u>160</u>	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
			<u>" " " to coarse</u>		<u>160</u>	<u>180</u>	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
			<u>fine Gravel brown + Clay hard</u>		<u>180</u>	<u>190</u>	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>40</u> ft.	
			<u>Clay + fine sand</u>		<u>190</u>	<u>206</u>	14 Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<u>Coarse sand + fine Gravel brown</u>		<u>206</u>	<u>220</u>	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Aermetor</u> Model number <u>SD-12-</u> HP <u>1 1/2</u> Volts <u>230</u> Length of drop pipe <u>320</u> ft. capacity <u>16</u> g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
<u>Sand medium coarse to fine</u>		<u>220</u>	<u>240</u>	16 Remarks: elevation <u>(19)</u> <u>Septic tank will be installed at a later date and over 100 feet to SW of Water Well</u>				
<u>Sand coarse + fine Gravel</u>		<u>240</u>	<u>260</u>	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Stocum Drilling 127</u> Business name License No. <u> </u> Address <u>Box 237 Hugoton K</u> Signed <u>Paul Stocum</u> Date <u>4-12-75</u> Authorized representative				
16 Remarks: elevation			(use a second sheet if needed)					