

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

Finchman A-2

CWW UNv. # 12606

1. Location of well: County Seward	Fraction 1/4 1/4SE 1/4	Section number 6	Township number T 34 S R 33	Range number EAM																							
2. Distance and direction from nearest town or city: 3/4 North and West to location of Liberal Street address of well location if in city:		3. Owner of well: Cities Service Oil Co. R.R. or street: 3545 N.W. 58th Street City, state, zip code: Okla. City, Okla., 73112																									
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>Sketch map:</p> </div> <div> <p>6. Bore hole dia. 9 in. Completion date 8-16-76 Well depth 280 ft.</p> <p>7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.78 lbs./ft. Dia. 5 in. to 280 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .265</p> </div> </div>																											
5. Type and color of material <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;"></th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr> <td>Surface</td> <td>0</td> <td>2</td> </tr> <tr> <td>Sandy clay and Clay</td> <td>2</td> <td>18</td> </tr> <tr> <td>Fine sand & Med. to large sand</td> <td>18</td> <td>94</td> </tr> <tr> <td>Clay, Fine sand and Med. to large sand</td> <td>94</td> <td>160</td> </tr> <tr> <td>Medium to large sand</td> <td>160</td> <td>200</td> </tr> <tr> <td>Clay, Fine sand & Med. to large sand</td> <td>200</td> <td>240</td> </tr> <tr> <td>Medium to large sand</td> <td>240</td> <td>280</td> </tr> </tbody> </table>			From	To	Surface	0	2	Sandy clay and Clay	2	18	Fine sand & Med. to large sand	18	94	Clay, Fine sand and Med. to large sand	94	160	Medium to large sand	160	200	Clay, Fine sand & Med. to large sand	200	240	Medium to large sand	240	280	10. Screen: Manufacturer's name sawed perf. Type PVC Dia. 5" Slot/gauze .030 Length 80 Set between 195 ft. and 275 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/8 to 3/16	
	From	To																									
Surface	0	2																									
Sandy clay and Clay	2	18																									
Fine sand & Med. to large sand	18	94																									
Clay, Fine sand and Med. to large sand	94	160																									
Medium to large sand	160	200																									
Clay, Fine sand & Med. to large sand	200	240																									
Medium to large sand	240	280																									
(Use a second sheet if needed)		11. Static water level: 120 ft. below land surface Date 8-16-76 12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping 60 g.p.m. Estimated maximum yield _____ g.p.m. 13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____ 14. Well head completion: _____ Pitless adapter 28 Inches above grade 15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to 10 ft. 16. Nearest source of possible contamination: ft. 100 Direction NE Type oilwell Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																									
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name License No. Address Box 275 Liberal, Ks Signed Edward E. Means Date 8-26 Authorized representative																										

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5