

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEWARD	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 10	Township number T 34 S	Range number R 33 E
2. Distance and direction from nearest town or city: 2m N. Liberal 2m E 1m N. Street address of well location if in city:				3. Owner of well: DARREL WEBB R.R. or street: RR 2 City, state, zip code: Liberal Kansas 67901		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 9 in. Completion date 10-8-80 Well depth 300 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Overburden		0	180	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 36 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 240 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0258		
medium to coarse sand		180	220	10. Screen: Manufacturer's name Lone Star Type PVC Dia. 5" Slot/gauze 1/16 Length 60' Set between 240 ft. and 300 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.		
medium sand + clay		220	260	Gravel pack? YES Size range of material 1/8		
medium to coarse sand + clay		260	300	11. Static water level: <input type="checkbox"/> mp./day/yr. 180 ft. below land surface Date 10/8/80		
				12. Pumping level below land surfaces: 12 ft. after 2 hrs. pumping 30 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
				16. Nearest source of possible contamination: ft. 175 Direction NW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name GOULDS Model number <input type="checkbox"/> HP 1 Volts 230 Length of drop pipe 210 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+W Water Well Service HA2 Business name HA2 License No. HA2 Address Box 816 Liberal KS 67901 Signature [Signature] Date 10/27/80 Authorized representative				