

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stevens	Fraction NE 1/4 SW 1/4 SE 1/4	Section number 23	Township number T 34 S R 35	Range number 35
2. Distance and direction from nearest town or city: 9 1/2 West, 1/4 NE of Liberal, Kansas Street address of well location if in city:				3. Owner of well: R. L. Hatcher R.R. or street: 1731 James Court City, state, zip code: Liberal, KS 67901		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: SE 1/4, Sec. 23, T34S, R35W, Stevens County, Kansas.				6. Bore hole dia. 28 in. Completion date _____ Well depth 456 ft. 3-6-79		
5. Type and color of material				7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: _____ Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____		
				9. Casing: Material Steel Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface _____ 12 in. RMP _____ PVC _____ Weight 37 lbs./ft. Dia 16 in. to 262 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 219		
				10. Screen: Manufacturer's name Foster, Doerr Type M/S, Louver Dia. 16" Slot/gauze 1/16" Length 194 Set between 262 ft. and 456 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 2.0 mm		
				11. Static water level: _____ mo./day/yr. 160 ft. below land surface Date 12-12-78		
12. Pumping level below land surfaces: 224 ft. after 1 1/2 hrs. pumping 1040 g.p.m. 270 ft. after 1 hrs. pumping 1471 g.p.m. Estimated maximum yield 1500 g.p.m.				13. Water sample submitted: _____ mo./day/yr. _____ Yes <input checked="" type="checkbox"/> No _____ Date _____		
14. Well head completion: _____ _____ Pitless adapter 12 Inches above grade				15. Well grouted? Yes <input checked="" type="checkbox"/> With: _____ Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: Unknown ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____				17. Pump: _____ Not installed Manufacturer's name WellLine Model number 12KEH HP 120 Volts _____ Length of drop pipe 300 ft. capacity 1000 g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ _____ Jet _____ Reciprocating _____ _____ Centrifugal _____ Other _____		
18. Elevation:				19. Remarks:		
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name _____ License No. _____ Address Garden City, KS 67846 Signed Steve Lugin Date 2-7-79 Authorized representative		