


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stevens	Fraction SW 1/4 NE 1/4	Section number 34	Township number T 34	Range number S R 35 E/W
2. Distance and direction from nearest town or city: 8 1/2 SOUTH OF HUGOTON, KAN.			3. Owner of well: Walter Littell R.R. or street: HUGOTON, KAN 66451 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 3/17/96 Well depth 710 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Overburden		0	2	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42.5 lbs./ft. Dia. 16 in. to 710 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
Top Soil		2	100	10. Screen Manufacturer's name L.B. Foster		
Coarse Sd. & Clay		100	140	Type Steel Dia. 16" Slot/gauze 1/8 Length 3 Set between 293 ft. and 690 ft. 690 ft. and 710 ft.		
Clay & Rock & Fine Sd.		140	200	Gravel pack? yes Size range of material 1/8-1/4		
Med. & Fine Sd. & Clay		200	280	11. Static water level: <input type="checkbox"/> mo./day/yr. 109 ft. below land surface Date 3/10/96		
Fine Sd. & Clay		280	320	12. Pumping level below land surfaces: NA ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
Med. & Fine Sd. & Clay		320	480	13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
Fine Sd. AND Clay		480	560	14. Well head completion: NR ____ Pitless adapter ____ Inches above grade		
Fine Sd. & Rock w/Clay		560	620	15. Well grouted? yes With: ____ Neat cement <input checked="" type="checkbox"/> Bentonite ____ Concrete Depth: From 0 ft. to 10 ft.		
Med. Sd. w/Clay		620	710	16. Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
Red Bed & Clay		710	733	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks: 10A Johnson Steel 16' 11000 Slot 690-690 164 Crop Land		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief: KTM DRILLING, INC. 225 Business name _____ License No. _____ Address Box 1385, Guymon, OK 73545 Signed [Signature] Date [Signature] Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

34 35E 34
T R Sec
1/4 1/4 1/4
SUSANNA