


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stevens	Fraction SE 1/4 NW 1/4	Section number 2	Township number T 34 S	Range number R 36 E/W
2. Distance and direction from nearest town or city: 3 1/4 South of Hugoton			3. Owner of well: Doug Mills R.R. or street: Box 72A City, state, zip code: Hugoton KS 67951			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 4/5/77 Well depth 645 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Overburden		0	2	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42.5 lbs./ft. Dia. 16 in. to 645 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 250		
Top Soil		2	200	10. Screen: Manufacturer's name L.B. Foster Type Steel Dia. 16" Slot/gauze 1/8 Length 360 Set between 255 ft. and 600 ft. 630 ft. and 645 ft. Gravel pack? yes Size range of material 18-1/4		
Fine Sd. & Clay		200	290	11. Static water level: 149 ft. below land surface Date 2-8-77 mo./day/yr.		
Fine & Med. Sd. w/Clay		290	350	12. Pumping level below land surfaces: NA ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
Med. & Coarse Sd.		350	400	13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
Coarse Sd. w/Clay Strks.		400	560	14. Well head completion: ____ Pitless adapter NA ____ Inches above grade		
Coarse Sd.		560	630	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Coarse Sd. & Gravel		630	640	16. Nearest source of possible contamination: ____ ft. ____ Direction ____ Type ____ Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
Red Bed		640	663	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other ____		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KTM DRILLING, INC. 225 Business name Box 1383 Guyman, Okla. Address Signed John Guyman Date 2/2/77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		(Use a second sheet if needed) 10A Johnson FR Steel 1/8" 1000 sht 600-630' 16A Crop Land				