


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County Stevens	Township name NW1/4,NW1/4,SW1/4	Fraction 26	Section number T 34 S	Town number R 36 W
Distance and direction from nearest town or city: 7 east & 7 south of Hugoton Street address of well location if in city:				3 Owner of well: Frank Thomas Address: Hugoton, KS		
Locate with "X" in section below: N  W X E S 1 Mile		Sketch map:		4 Well depth: <u>382</u> ft. Date of completion <u>5-1-75</u> Well diameter <u>9 7/8</u> in.		
2 Type and color of material See Attachment		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
		7 Casing: Material <u>Plastic</u> Height: <u>above</u> below Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Dia. _____ Weight _____ lbs./ft. _____ <u>5</u> in. to <u>382</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth				
		8 Screen: Manufacturer <u>Jess & Lowell</u> Type <u>Slotted</u> Dia. <u>5"</u> Slot/gauze <u>.060</u> Length <u>50'</u> Set between <u>332</u> ft. and <u>382</u> ft. _____ Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/8"</u>				
		9 Static water level: <u>135</u> ft. below land surface Date <u>5-1-75</u>				
		10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.				
		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____				
		12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade				
		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.				
		14 Nearest source of possible contamination: ft. <u>125</u> Direction <u>east</u> Type <u>Septic Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
		15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <u>Flat</u> <input type="checkbox"/> Upland <input type="checkbox"/> Valley		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Henkle Drilling & Supply 145</u> Business name _____ License No. _____ Address <u>Box 639 Garden City, KS</u> Signed <u>James H. Henkle</u> Date <u>5/16/75</u> Authorized representative				

DRILLERS TEST LOG

CUSTOMERS NAME Frank Thomas DATE 4-29-75
 STREET ADDRESS _____ TEST # Hausewall H-Log 448
 CITY & STATE Hugoton, KS DRILLER Baxter
 COUNTY Stevens QUARTER SW SECTION 26 TOWNSHIP 14 RANGE 36

LOCATION 15 ft. S & W of trailer house

%	DRILLED FOOTAGE		Static Water Level	
	from	Pay to	Description of Strata	Proposed Well Depth
	0		5	Top soil
	6		60	Brown clay & few sand st.
	60		70	Sand & gravel
	70		80	Brown sandy clay & sand
	80		160	Brown clay & caliche
	160		184	Brown clay & Gyp rock st.
	184		200	Sand fine to med. coarse, & med. small sand
	200		220	Brown clay, Gyp rock & caliche
	220		255	Brown sandy clay, fine sand, & caliche
30	255	13	268	Brown sandy clay, fine sand & caliche
	268		300	Brown sandy clay, caliche & sand
	300		320	Brown clay, caliche, & Gyp rock
	320		330	Limestone, Gyp rock, Chert, & Quartzite. (Hard used Pull down) 600# Hyd. Pressure
50	330	50	380	Sand fine to med. coarse, small coarse, & very fine sandy clay st. (loose) used water.
	380		460	Brown & blue clay & very hard limestone st.
	460		480	Sandy blue clay
				Set 382 ft. Plastic Casing